

Radiation Report

SN54SC6T07-SEP Total Ionizing Dose (TID) Report



ABSTRACT

This report discusses the radiation characterization results of the SN54SC6T07-SEP radiation tolerant, hex open-drain buffer with integrated translation. The study was done to determine Total Ionizing Dose (TID) effects under high dose rate (HDR) up to 50krad(Si) as a one time characterization. The results show that all samples passed within the specified limits up to 50krad(Si). Radiation Lot Acceptance Testing (RLAT) will be performed using five units at a dose level of 30 krad(Si) for future wafer lots per MIL-STD-883 TM 1019.

The SN54SC6T07-SEP is packaged in a space enhanced plastic for low outgassing characteristics and is Single Event Latch-Up (SEL) immune up to 43MeV-cm² / mg, which makes the device an option for low Earth orbit space applications.

The SN54SC6T07-SEP Total Ionizing Dose (TID) Report covers the TID performance of all four devices listed below. The SN54SC6T07-SEP device covers all functional blocks and active die area of the other three devices, which is why the device was selected for total ionizing dose testing for this group of voltage translation devices.

- SN54SC6T07-SEP
- SN54SC6T06-SEP
- SN54SC6T14-SEP
- SN54SC6T17-SEP

Table of Contents

1 Device Information	2
1.1 Device Details.....	2
2 Total Dose Test Setup	3
2.1 Test Overview.....	3
2.2 Test Description and Facilities.....	3
2.3 Test Setup Details.....	3
2.4 Test Configuration and Condition.....	4
3 TID Characterization Test Results	5
3.1 TID Characterization Summary Results.....	5
3.2 Specification Compliance Matrix.....	6
4 Reference Documents	8
5 Appendix: HDR TID Report Data	8

List of Figures

Figure 2-1. SN54SC6T07-SEP Biased Diagram.....	3
--	---

List of Tables

Table 1-1. Device and Exposure Details.....	2
Table 2-1. HDR Device Information.....	4
Table 3-1. Electrical Parameters Table.....	6

Trademarks

All trademarks are the property of their respective owners.

1 Device Information

The SN54SC6T07-SEP device contains six independent buffers with open-drain outputs and extended voltage operation to allow for level translation. Each buffer performs the Boolean function $Y = A$ in positive logic. The output level is referenced to the supply voltage (VCC) and supports 1.2V, 1.8V, 2.5V, 3.3V, and 5V CMOS levels.

The input is designed with a lower threshold circuit to support up translation for lower voltage CMOS inputs (for example 1.2V input to 1.8V output or 1.8V input to 3.3V output). Additionally, the 5V tolerant input pins enable down translation (for example 3.3V to 2.5V output).

1.1 Device Details

Table 1-1 lists the device information used for TID HDR characterization and qualification.

Table 1-1. Device and Exposure Details

TID HDR Details: up to 50 krad(Si)	
TI Device Number	SN54SC6T07-SEP
Package	14-pin PW (TSSOP)
Technology	LBC9
Die Lot Number	2208585RFB
A/T Lot Number and Date Code	3288329ML3 / 33AF4CK
Quantity Tested	27 irradiated devices + four control
Lot Accept or Reject	Devices passed 30krad(Si)
HDR Radiation Facility	Texas Instruments CLAB in Dallas, Texas
HDR Dose Level	10krad(Si), 20krad(Si), 30krad(Si), 50krad(Si)
HDR Dose Rate	192.51 -rad(Si) /s ionizing radiation
HDR Radiation Source	Gammacell 220 Excel (GC-220E) Co-60
Irradiation Temperature	Ambient, room temperature

2 Total Dose Test Setup

2.1 Test Overview

The SN54SC6T07-SEP samples were irradiated at a high dose rate of 192.51rad(Si) / s up to 50krad(Si) and then put through full electrical parametric testing on the production Automated Test Equipment (ATE). The samples were functional and passed all electrical parametric tests with readings within data sheet electrical specification limits.

2.2 Test Description and Facilities

The SN54SC6T07-SEP HDR exposure was performed on biased and unbiased devices in a Co-60 gamma cell at a TI facility in Dallas, Texas. The unattenuated dose rate of this cell is 192.51 rads(Si) / s. After exposure, the devices were packed in dry ice (per MIL-STD-883 Method 1019.9 section 3.10) and full post radiation electrical evaluation using Texas Instruments ATE was conducted. ATE test limits are set per data sheet electrical limits based on qualification and characterization data. Post radiation measurements were taken within 30 minutes of removing the devices from the dry ice container. The devices were allowed to reach room temperature prior to electrical post radiation measurements.

2.3 Test Setup Details

The devices were tested in biased conditions as described in the following sections.

2.3.1 Bias Diagram

Figure 2-1 shows the bias conditions for each pin during irradiation.




Figure 2-1. SN54SC6T07-SEP Biased Diagram

2.4 Test Configuration and Condition

A step stress (10k, 20k, 30k and 50k) test method was used to determine the TID hardness level. That is, after a predetermined TID level was reached, an electrical test was performed on a given sample of parts to verify that the units are within specified data sheet electrical test limits. The RLAT units were parametrically tested on ATE and then put through 25°C anneal for 72 hours. The units were then put through parametric testing again on the ATE.

Table 2-1 lists the serialized samples used for TID characterization.

Table 2-1. HDR Device Information

Control Group		HDR = 192.51rad(Si)/s				
Total Samples: 4		Total Samples: 27				
		Exposure Levels				
0krad (Si)	10krad (Si)	20krad(Si)	30krad(Si)		50krad (Si)	
Biased	Biased	Biased	Biased	Biased + 72 hour anneal	Biased	
1 - 4	5 - 9	10 - 14	15 - 20	21 - 26	27 - 31	

3 TID Characterization Test Results

3.1 TID Characterization Summary Results

The parametric data for the SN54SC6T07-SEP passes up to 30krad(Si) HDR TID irradiation. The drifts of the electrical parameters through HDR were within the data sheet limits.

Overall, the SN54SC6T07-SEP showed a strong degree of hardness to HDR TID irradiation up to 30krad(Si). The measurements taken post-irradiation for each sample set showed a marginal shift for most parameters at each dose level. The parameters that showed a greater degree of change between pre- and post-irradiation were within the electrical performance characteristics specified in the data sheet electrical parameters.

See [Section 5](#) for HDR report up to 50krad(Si).

3.2 Specification Compliance Matrix

Table 3-1. Electrical Parameters Table

Parameter	Test Conditions	V _{CC}	T _A = -55°C to +125°C			Unit	Test Name
			MIN	TYP	MAX		
V _{T+} 1	Positive-going input threshold voltage	1.2V to 1.3V	0.31	0.655	1.1	V	VTP_1P2V
		1.65V to 2V	0.39	0.915	1.32		VTP_1P65V, VTP_2V
		2.25V to 2.75V	0.51	1.09	1.51		VTP_2P25V, VTP_2P75V
		3V to 3.6V	0.65	1.2	1.7		VTP_3V, VTP_3P6V
		4.5V to 5.5V	0.87	1.51	2.16		VTP_4P5V, VTP_5P5V
V _{T-} 1	Negative-going input threshold voltage	1.2V to 1.3V	0.11	0.349	0.622	V	VTN_1P2V
		1.65V to 2V	0.18	0.455	0.666		VTN_1P65V, VTN_2V
		2.25V to 2.75V	0.25	0.545	0.74		VTN_2P25V, VTN_2P75V
		3V to 3.6V	0.33	0.635	0.85		VTN_3V, VTN_3P6V
		4.5V to 5.5V	0.45	0.755	1.14		VTN_4P5V, VTN_5P5V
ΔV _T 1	Hysteresis (VT+ – VT-)	1.2V to 1.3V	0.081	0.29	0.77	V	DELTAVT_1P2V
		1.65V to 2V	0.21	0.43	0.88		DELTAVT_1P65V, DELTAVT_2V
		2.25V to 2.75V	0.25	0.54	0.91		DELTAVT_2P25V, DELTAVT_2P75V
		3V to 3.6V	0.31	0.63	0.91		DELTAVT_3V, DELTAVT_3P6V
		4.5V to 5.5V	0.43	0.75	1.1		DELTAVT_4P5V, DELTAVT_5P5V
V _{IH}	High-level input voltage	1.2V to 1.3V	0.78			V	VIH_1P2V, VIH_1P3V
		1.65V to 2V	1.1				VIH_1P65V, VIH_2V
		2.25V to 2.75V	1.28				VIH_2P25V, VIH_2P75V
		3V to 3.6V	1.45				VIH_3V, VIH_3P6V
		4.5V to 5.5V	2				VIH_4P5V, VIH_5P5V
V _{IL}	Low-level input voltage	1.2V to 1.3V			0.18	V	VIL_1P2V, VIL_1P3V
		1.65V to 2V			0.51		VIL_1P65V, VIL_2V
		2.25V to 2.75V			0.65		VIL_2P25V, VIL_2P75V
		3V to 3.6V			0.75		VIL_3V, VIL_3P6V
		4.5V to 5.5V			0.8		VIL_4P5V, VIL_5P5V
V _{OH} 2	I _{OH} = -50µA	1.2V to 5.5V	V _{CC} -0.2			V	VOH_N50UA_1P65V, VOH_N50UA_2V, VOH_N50UA_2P75V, VOH_N50UA_3P6V, VOH_N50UA_4P5V, VOH_N50UA_5P5V
	I _{OH} = -1mA	1.2V	0.8				VOH_N1MA_1P2V
	I _{OH} = -2mA	1.65V to 2V	1.21				VOH_N2MA_1P65V, VOH_N2MA_2V
	I _{OH} = -3mA	2.25V to 2.75V	1.93				VOH_N3MA_2P25V, VOH_N3MA_2P75V
	I _{OH} = -5.5mA	3V to 3.6V	2.49				VOH_N5P5MA_3V, VOH_N5P5MA_3P6V
	I _{OH} = -8mA	4.5V to 5.5V	3.95				VOH_N8MA_4P5V, VOH_N8MA_5P5V
	I _{OH} = -24mA	4.5V to 5.5V	3.15				VOH_N24MA_4P5V, VOH_N24MA_5P5V
V _{OL}	I _{OL} = 50µA	1.2V to 5.5V			0.1	V	VOL_50UA_1P65V, VOL_50UA_2V, VOL_50UA_2P75V, VOL_50UA_3P6V, VOL_50UA_4P5V, VOL_50UA_5P5V
	I _{OL} = 1mA	1.2V			0.2		VOL_1MA_1P2V
	I _{OL} = 2mA	1.65V to 2V			0.25		VOL_2MA_1P65V, VOL_2MA_2V
	I _{OL} = 3mA	2.25V to 2.75V			0.2		VOL_3MA_2P25V, VOL_3MA_2P75V
	I _{OL} = 5.5mA	3V to 3.6V			0.25		VOL_5P5MA_3V, VOL_5P5MA_3P6V
	I _{OL} = 8mA	4.5V to 5.5V			0.35		VOL_8MA_4P5V, VOL_8MA_5P5V
	I _{OL} = 24mA	4.5V to 5.5V			0.75		VOL_24MA_4P5V, VOL_24MA_5P5V
I _{CC}	V _i = V _{CC} or GND, I _O = 0	1.2V to 5.5V		2	93	µA	ICCH_5P5V, ICCL_5P5V

Table 3-1. Electrical Parameters Table (continued)

Parameter	Test Conditions	V _{CC}	T _A = -55°C to +125°C			Unit	Test Name
			MIN	TYP	MAX		
ΔI_{CC}	One input at 0.3V or 3.4V, other inputs at V _{CC} or GND	5.5V			1.5	mA	DELTACC_5P5V
	One input at 0.3V or 1.1V, other inputs at V _{CC} or GND	1.8V			68	µA	DELTACC_1P8V
I _{OZ} ³	V _O = V _{CC} or GND	5.5V			±2.5	µA	IOZ
I _I	V _I = 0V to V _{CC}	V _I = 0V to V _{CC}			±1	µA	IIH_5P5V, III_5P5V

1. Schmitt-trigger input devices only.
2. Push-pull output devices only.
3. Tri-state output devices only.

4 Reference Documents

Texas Instruments total ionizing dose radiation (total dose) test procedure follows the standards put forth in MIL-STD-883 TM 1019. The document can be found at the DLA website.


5 Appendix: HDR TID Report Data

This appendix provides the SN54SC6T07-SEP TID HDR report. The report shows the variation for each parameter up to 50krad(Si).


TID Report

SN54SC6T07-SEP

DETAICC_1P8V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	68					
Min Limit	-10					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	3.167	2.823	-0.34	-10.86%	0.44%
0	2	2.917	2.854	-0.06	-2.16%	0.08%
0	3	3.136	3.042	-0.09	-3.00%	0.12%
0	4	3.073	2.917	-0.16	-5.08%	0.20%
10	5	2.948	2.854	-0.09	-3.19%	0.12%
10	6	3.073	3.073	0.00	0.00%	0.00%
10	7	3.073	2.885	-0.19	-6.12%	0.24%
10	8	3.011	3.073	0.06	2.06%	0.08%
10	9	2.854	2.917	0.06	2.21%	0.08%
20	10	2.979	2.885	-0.09	-3.16%	0.12%
20	11	3.261	3.073	-0.19	-5.77%	0.24%
20	12	3.073	2.979	-0.09	-3.06%	0.12%
20	13	3.011	3.136	0.13	4.15%	0.16%
20	14	3.198	2.948	-0.25	-7.82%	0.32%
30	15	3.104	7.330	4.23	136.15%	5.42%
30	16	3.073	6.579	3.51	114.09%	4.49%
30	17	2.979	7.831	4.85	162.87%	6.22%
30	18	3.011	6.986	3.98	132.02%	5.10%
30	19	3.073	6.548	3.48	113.08%	4.46%
30	20	3.230	6.642	3.41	105.63%	4.37%
31	21	3.104	5.264	2.16	69.59%	2.77%
31	22	3.073	5.014	1.94	63.16%	2.49%
31	23	2.979	5.577	2.60	87.21%	3.33%
31	24	3.011	5.452	2.44	81.07%	3.13%
31	25	3.073	5.139	2.07	67.23%	2.65%
31	26	3.230	5.014	1.78	55.23%	2.29%
50	27	3.073	129.300	126.23	4107.61%	161.83%
50	28	2.979	105.800	102.82	3451.53%	131.82%
50	29	2.948	110.300	107.35	3641.52%	137.63%
50	30	3.042	105.000	101.96	3351.68%	130.72%
50	31	3.104	84.340	81.24	2617.14%	104.15%
Max		3.261	129.300	126.04	4107.61%	161.83%
Average		3.059	18.841	15.78	523.26%	20.37%
Min		2.854	2.823	-0.03	-10.86%	0.00%
Std Dev		0.095	37.617	37.52	1248.39%	48.19%




DETAICC_1P8V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	68					
Min Limit	-10					
krad	0	10	20	30	31	50
LL	-10.00	-10.00	-10.00	-10.00	-10.00	-10.00
Min	2.82	2.85	2.89	2.95	5.01	5.01
Average	2.91	2.96	3.00	6.33	5.81	66.57
Max	3.04	3.07	3.14	7.83	6.64	129.30
UL	68.00	68.00	68.00	68.00	68.00	68.00




TID Report

SN54SC6T07-SEP

DETAICC_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	1500					
Min Limit	-10					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	92.260	92.160	-0.10	-0.11%	0.01%
0	2	92.350	92.100	-0.25	-0.27%	0.02%
0	3	92.220	91.940	-0.28	-0.30%	0.02%
0	4	91.190	91.030	-0.16	-0.18%	0.01%
10	5	91.380	91.000	-0.38	-0.42%	0.03%
10	6	91.470	91.410	-0.06	-0.07%	0.00%
10	7	92.440	91.940	-0.50	-0.54%	0.03%
10	8	92.440	91.940	-0.50	-0.54%	0.03%
10	9	91.660	91.540	-0.12	-0.13%	0.01%
20	10	91.790	91.570	-0.22	-0.24%	0.01%
20	11	92.040	91.030	-1.01	-1.10%	0.07%
20	12	91.500	90.880	-0.62	-0.68%	0.04%
20	13	91.570	91.000	-0.57	-0.62%	0.04%
20	14	91.720	91.100	-0.62	-0.68%	0.04%
30	15	92.070	96.260	4.19	4.55%	0.28%
30	16	91.850	95.640	3.79	4.13%	0.25%
30	17	91.940	96.920	4.98	5.42%	0.33%
30	18	91.630	95.390	3.76	4.10%	0.25%
30	19	92.100	95.200	3.10	3.37%	0.21%
30	20	92.040	95.510	3.47	3.77%	0.23%
31	21	92.070	94.350	2.28	2.48%	0.15%
31	22	91.850	93.820	1.97	2.14%	0.13%
31	23	91.940	94.230	2.29	2.49%	0.15%
31	24	91.630	94.230	2.60	2.84%	0.17%
31	25	92.100	93.980	1.88	2.04%	0.12%
31	26	92.040	93.980	1.94	2.11%	0.13%
50	27	91.440	256.400	164.96	180.40%	10.92%
50	28	91.160	225.600	134.44	147.48%	8.90%
50	29	91.630	233.700	142.07	155.05%	9.41%
50	30	91.910	228.600	136.69	148.72%	9.05%
50	31	91.100	198.900	107.80	118.33%	7.14%
Max		92.440	256.400	163.96	180.40%	10.92%
Average		91.848	112.148	20.30	22.17%	1.37%
Min		91.160	90.880	-0.28	-1.10%	0.00%
Std Dev		0.345	49.675	49.33	54.41%	3.29%




DETAICC_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	1500					
Min Limit	-10					
krad	0	10	20	30	31	50
LL	-10.00	-10.00	-10.00	-10.00	-10.00	-10.00
Min	91.94	91.00	90.88	91.10	93.82	93.98
Average	92.07	91.46	91.20	95.06	94.62	175.21
Max	92.16	91.94	91.57	96.92	95.51	256.40
UL	1500.00	1500.00	1500.00	1500.00	1500.00	1500.00




TID Report

SN54SC6T07-SEP

ICC						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	93					
Min Limit	-1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.003	0.003	0.00	-16.39%	0.00%
0	2	0.003	0.003	0.00	5.01%	0.00%
0	3	0.003	0.003	0.00	-3.14%	0.00%
0	4	0.003	0.003	0.00	-21.03%	0.00%
10	5	0.003	0.003	0.00	4.27%	0.00%
10	6	0.003	0.003	0.00	9.24%	0.00%
10	7	0.003	0.004	0.00	31.19%	0.00%
10	8	0.003	0.003	0.00	16.92%	0.00%
10	9	0.003	0.003	0.00	4.27%	0.00%
20	10	0.003	0.063	0.06	2235.32%	0.06%
20	11	0.003	0.149	0.15	5334.31%	0.16%
20	12	0.003	0.232	0.23	7901.38%	0.24%
20	13	0.003	0.198	0.19	6438.72%	0.21%
20	14	0.003	0.052	0.05	1683.47%	0.05%
30	15	0.003	6.173	6.17	200062.13%	6.56%
30	16	0.003	5.371	5.37	202808.95%	5.71%
30	17	0.003	7.061	7.06	260549.69%	7.51%
30	18	0.003	5.583	5.58	190576.23%	5.94%
30	19	0.003	5.157	5.15	170548.58%	5.48%
30	20	0.003	5.240	5.24	168064.31%	5.57%
31	21	0.003	3.053	3.05	98894.81%	3.24%
31	22	0.003	2.868	2.87	108249.07%	3.05%
31	23	0.003	3.559	3.56	131276.89%	3.78%
31	24	0.003	3.469	3.47	118376.78%	3.69%
31	25	0.003	2.837	2.83	93778.23%	3.01%
31	26	0.003	2.872	2.87	92069.45%	3.05%
50	27	0.003	191.200	191.20	6978002.19%	203.40%
50	28	0.003	155.600	155.60	5370973.52%	165.53%
50	29	0.003	165.000	165.00	5757052.83%	175.53%
50	30	0.003	154.100	154.10	4896627.04%	163.93%
50	31	0.003	123.400	123.40	4083288.48%	131.27%
Max		0.003	191.200	191.20	6978002.19%	203.40%
Average		0.003	23.995	23.99	828717.81%	25.52%
Min		0.003	0.003	0.00	-21.03%	0.00%
Std Dev		0.000	57.153	57.15	1985899.77%	60.80%






ICC						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	93					
Min Limit	-1					
krad	0	10	20	30	31	50
LL	-1.00	-1.00	-1.00	-1.00	-1.00	-1.00
Min	0.00	0.00	0.00	0.05	2.87	2.84
Average	0.00	0.00	0.13	4.85	3.98	96.44
Max	0.00	0.00	0.23	7.06	5.24	191.20
UL	93.00	93.00	93.00	93.00	93.00	93.00



TID Report

SN54SC6T07-SEP


IIH_5p5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	1					
Min Limit	-1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.004	0.004	0.00	0.00%	0.00%
0	2	0.004	0.004	0.00	-2.45%	0.01%
0	3	0.004	0.004	0.00	11.57%	0.02%
0	4	0.004	0.004	0.00	13.09%	0.03%
10	5	0.004	0.004	0.00	-6.40%	0.01%
10	6	0.004	0.004	0.00	12.51%	0.02%
10	7	0.004	0.004	0.00	4.95%	0.01%
10	8	0.004	0.004	0.00	6.39%	0.01%
10	9	0.004	0.004	0.00	-1.54%	0.00%
20	10	0.004	0.004	0.00	-4.63%	0.01%
20	11	0.004	0.004	0.00	-2.80%	0.01%
20	12	0.004	0.004	0.00	-2.98%	0.01%
20	13	0.004	0.004	0.00	5.86%	0.01%
20	14	0.004	0.004	0.00	2.98%	0.01%
30	15	0.004	0.004	0.00	2.94%	0.01%
30	16	0.004	0.004	0.00	0.00%	0.00%
30	17	0.004	0.004	0.00	15.62%	0.03%
30	18	0.004	0.005	0.00	25.17%	0.05%
30	19	0.004	0.004	0.00	15.01%	0.03%
30	20	0.004	0.004	0.00	10.34%	0.02%
31	21	0.004	0.004	0.00	-5.27%	0.01%
31	22	0.004	0.004	0.00	9.51%	0.02%
31	23	0.004	0.004	0.00	9.56%	0.02%
31	24	0.004	0.004	0.00	9.34%	0.02%
31	25	0.004	0.004	0.00	1.43%	0.00%
31	26	0.004	0.004	0.00	12.91%	0.03%
50	27	0.004	0.008	0.00	92.35%	0.20%
50	28	0.004	0.006	0.00	36.30%	0.08%
50	29	0.004	0.004	0.00	1.56%	0.00%
50	30	0.004	0.005	0.00	7.30%	0.02%
50	31	0.004	0.004	0.00	-7.88%	0.02%
Max		0.004	0.008	0.00	92.35%	0.20%
Average		0.004	0.004	0.00	9.35%	0.02%
Min		0.004	0.004	0.00	-6.40%	0.00%
Std Dev		0.000	0.001	0.00	18.21%	0.04%




TID Report

SN54SC6T07-SEP

III_L_5p5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	1					
Min Limit	-1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.001	0.002	0.00	61.25%	0.04%
0	2	0.004	0.005	0.00	7.12%	0.02%
0	3	0.003	0.005	0.00	69.51%	0.11%
0	4	0.003	0.003	0.00	0.00%	0.00%
10	5	0.002	0.003	0.00	82.34%	0.08%
10	6	0.002	0.001	0.00	-25.76%	0.03%
10	7	0.001	0.004	0.00	198.11%	0.14%
10	8	0.003	0.007	0.00	161.12%	0.20%
10	9	0.002	0.004	0.00	84.88%	0.09%
20	10	0.003	0.004	0.00	9.05%	0.02%
20	11	0.006	0.002	0.00	-71.32%	0.20%
20	12	0.004	0.002	0.00	-63.95%	0.14%
20	13	0.007	0.002	0.00	-74.00%	0.25%
20	14	0.006	0.002	0.00	-68.57%	0.19%
30	15	0.006	0.003	0.00	-44.85%	0.14%
30	16	0.005	0.003	0.00	-37.34%	0.09%
30	17	0.004	0.003	0.00	-38.27%	0.08%
30	18	0.001	0.002	0.00	29.62%	0.02%
30	19	0.002	0.003	0.00	85.73%	0.07%
30	20	0.002	0.002	0.00	39.40%	0.03%
31	21	0.006	0.002	0.00	-73.68%	0.23%
31	22	0.005	0.004	0.00	-18.67%	0.05%
31	23	0.004	0.001	0.00	-69.50%	0.14%
31	24	0.001	0.001	0.00	-6.39%	0.00%
31	25	0.002	0.007	0.01	372.38%	0.29%
31	26	0.002	0.002	0.00	-5.71%	0.00%
50	27	0.003	0.003	0.00	9.92%	0.02%
50	28	0.001	-0.001	0.00	-142.09%	0.10%
50	29	0.004	0.001	0.00	-68.87%	0.14%
50	30	0.001	0.006	0.00	366.46%	0.24%
50	31	0.002	0.002	0.00	24.30%	0.02%
Max		0.007	0.007	0.00	372.38%	0.29%
Average		0.003	0.003	0.00	25.60%	0.11%
Min		0.001	-0.001	0.00	-142.09%	0.00%
Std Dev		0.002	0.002	0.00	119.13%	0.08%






III_L_5p5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	μA					
Max Limit	1					
Min Limit	-1					
krad	0	10	20	30	31	50
LL	-1.00	-1.00	-1.00	-1.00	-1.00	-1.00
Min	0.00	0.00	0.00	0.00	0.00	0.00
Average	0.00	0.00	0.00	0.00	0.00	0.00
Max	0.01	0.01	0.00	0.00	0.01	0.01
UL	1.00	1.00	1.00	1.00	1.00	1.00



TID Report

SN54SC6T07-SEP




VIH_1P2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.78					
Min Limit	0.2					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.560	0.560	0.00	0.00%	0.00%
0	2	0.558	0.558	0.00	0.00%	0.00%
0	3	0.559	0.558	0.00	-0.07%	0.06%
0	4	0.558	0.557	0.00	-0.02%	0.02%
10	5	0.557	0.549	-0.01	-1.55%	1.49%
10	6	0.559	0.551	-0.01	-1.46%	1.41%
10	7	0.560	0.551	-0.01	-1.69%	1.63%
10	8	0.557	0.549	-0.01	-1.37%	1.32%
10	9	0.559	0.550	-0.01	-1.54%	1.49%
20	10	0.559	0.533	-0.03	-4.65%	4.48%
20	11	0.556	0.528	-0.03	-5.08%	4.87%
20	12	0.553	0.527	-0.03	-4.82%	4.60%
20	13	0.558	0.528	-0.03	-5.38%	5.17%
20	14	0.557	0.535	-0.02	-3.91%	3.75%
30	15	0.554	0.490	-0.06	-11.66%	11.14%
30	16	0.555	0.487	-0.07	-12.29%	11.77%
30	17	0.555	0.489	-0.07	-11.99%	11.48%
30	18	0.556	0.490	-0.07	-11.81%	11.32%
30	19	0.556	0.493	-0.06	-11.30%	10.84%
30	20	0.557	0.495	-0.06	-11.02%	10.58%
31	21	0.554	0.507	-0.05	-8.47%	8.09%
31	22	0.555	0.505	-0.05	-9.11%	8.72%
31	23	0.555	0.506	-0.05	-8.84%	8.46%
31	24	0.556	0.505	-0.05	-9.18%	8.80%
31	25	0.556	0.510	-0.05	-8.25%	7.91%
31	26	0.557	0.512	-0.04	-8.04%	7.72%
50	27	0.555	0.394	-0.16	-29.01%	27.75%
50	28	0.560	0.397	-0.16	-29.08%	28.08%
50	29	0.558	0.407	-0.15	-27.04%	26.03%
50	30	0.559	0.397	-0.16	-29.06%	28.03%
50	31	0.558	0.410	-0.15	-26.56%	25.55%
Max		0.560	0.560	0.00	0.00%	28.08%
Average		0.557	0.507	-0.05	-8.92%	8.57%
Min		0.553	0.394	-0.16	-29.08%	0.00%
Std Dev		0.002	0.050	0.05	8.85%	8.51%



TID Report

SN54SC6T07-SEP




VIH_1P3V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.78					
Min Limit	0.2					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.599	0.599	0.00	-0.03%	0.03%
0	2	0.599	0.598	0.00	-0.08%	0.08%
0	3	0.598	0.597	0.00	-0.10%	0.11%
0	4	0.597	0.597	0.00	0.00%	0.00%
10	5	0.596	0.588	-0.01	-1.34%	1.38%
10	6	0.597	0.590	-0.01	-1.17%	1.20%
10	7	0.600	0.592	-0.01	-1.29%	1.33%
10	8	0.595	0.588	-0.01	-1.22%	1.25%
10	9	0.598	0.589	-0.01	-1.39%	1.43%
20	10	0.598	0.575	-0.02	-3.87%	3.99%
20	11	0.594	0.569	-0.03	-4.31%	4.42%
20	12	0.592	0.568	-0.02	-4.02%	4.10%
20	13	0.596	0.570	-0.03	-4.38%	4.49%
20	14	0.595	0.576	-0.02	-3.20%	3.29%
30	15	0.593	0.539	-0.05	-9.08%	9.28%
30	16	0.594	0.535	-0.06	-10.00%	10.25%
30	17	0.595	0.537	-0.06	-9.66%	9.91%
30	18	0.595	0.539	-0.06	-9.41%	9.65%
30	19	0.595	0.542	-0.05	-8.90%	9.13%
30	20	0.596	0.544	-0.05	-8.79%	9.03%
31	21	0.593	0.554	-0.04	-6.57%	6.72%
31	22	0.594	0.552	-0.04	-7.15%	7.33%
31	23	0.595	0.553	-0.04	-7.04%	7.22%
31	24	0.595	0.552	-0.04	-7.18%	7.36%
31	25	0.595	0.556	-0.04	-6.51%	6.68%
31	26	0.596	0.557	-0.04	-6.51%	6.69%
50	27	0.594	0.451	-0.14	-23.97%	24.53%
50	28	0.599	0.456	-0.14	-23.87%	24.65%
50	29	0.597	0.466	-0.13	-21.92%	22.57%
50	30	0.599	0.456	-0.14	-23.91%	24.70%
50	31	0.597	0.467	-0.13	-21.82%	22.46%
Max		0.600	0.599	0.00	0.00%	24.70%
Average		0.596	0.553	-0.04	-7.23%	7.43%
Min		0.592	0.451	-0.14	-23.97%	0.00%
Std Dev		0.002	0.043	0.04	7.23%	7.45%



TID Report

SN54SC6T07-SEP




VIH_1P65V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.1					
Min Limit	0.5					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.723	0.723	0.00	0.01%	0.01%
0	2	0.722	0.721	0.00	-0.05%	0.06%
0	3	0.723	0.722	0.00	-0.05%	0.05%
0	4	0.721	0.721	0.00	-0.03%	0.03%
10	5	0.720	0.712	-0.01	-1.13%	1.35%
10	6	0.722	0.715	-0.01	-0.93%	1.11%
10	7	0.722	0.716	-0.01	-0.88%	1.06%
10	8	0.719	0.712	-0.01	-0.91%	1.10%
10	9	0.722	0.714	-0.01	-1.11%	1.34%
20	10	0.722	0.703	-0.02	-2.56%	3.08%
20	11	0.718	0.697	-0.02	-2.86%	3.42%
20	12	0.716	0.697	-0.02	-2.64%	3.15%
20	13	0.717	0.697	-0.02	-2.81%	3.36%
20	14	0.719	0.702	-0.02	-2.36%	2.83%
30	15	0.716	0.677	-0.04	-5.48%	6.55%
30	16	0.717	0.676	-0.04	-5.76%	6.88%
30	17	0.718	0.675	-0.04	-6.00%	7.18%
30	18	0.717	0.677	-0.04	-5.62%	6.71%
30	19	0.718	0.680	-0.04	-5.32%	6.36%
30	20	0.719	0.680	-0.04	-5.46%	6.55%
31	21	0.716	0.688	-0.03	-3.88%	4.64%
31	22	0.717	0.687	-0.03	-4.18%	5.00%
31	23	0.718	0.688	-0.03	-4.27%	5.12%
31	24	0.717	0.688	-0.03	-4.02%	4.80%
31	25	0.718	0.690	-0.03	-3.83%	4.58%
31	26	0.719	0.691	-0.03	-3.98%	4.77%
50	27	0.716	0.617	-0.10	-13.81%	16.48%
50	28	0.722	0.620	-0.10	-14.15%	17.03%
50	29	0.721	0.627	-0.09	-13.10%	15.74%
50	30	0.722	0.621	-0.10	-13.93%	16.76%
50	31	0.721	0.628	-0.09	-12.88%	15.47%
Max		0.723	0.723	0.00	0.01%	17.03%
Average		0.719	0.688	-0.03	-4.37%	5.24%
Min		0.716	0.617	-0.10	-14.15%	0.01%
Std Dev		0.002	0.031	0.03	4.19%	5.03%



TID Report

SN54SC6T07-SEP


VIH_2P25V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.28					
Min Limit	0.65					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.901	0.899	0.00	-0.12%	0.18%
0	2	0.897	0.897	0.00	-0.04%	0.06%
0	3	0.899	0.898	0.00	-0.10%	0.15%
0	4	0.895	0.896	0.00	0.11%	0.15%
10	5	0.897	0.891	-0.01	-0.71%	1.01%
10	6	0.898	0.891	-0.01	-0.78%	1.12%
10	7	0.897	0.890	-0.01	-0.81%	1.15%
10	8	0.896	0.890	-0.01	-0.69%	0.98%
10	9	0.898	0.890	-0.01	-0.86%	1.22%
20	10	0.896	0.881	-0.02	-1.71%	2.44%
20	11	0.895	0.877	-0.02	-2.00%	2.84%
20	12	0.893	0.878	-0.02	-1.73%	2.45%
20	13	0.893	0.876	-0.02	-1.93%	2.74%
20	14	0.894	0.879	-0.01	-1.64%	2.33%
30	15	0.894	0.864	-0.03	-3.34%	4.75%
30	16	0.893	0.863	-0.03	-3.41%	4.83%
30	17	0.894	0.864	-0.03	-3.31%	4.70%
30	18	0.894	0.864	-0.03	-3.37%	4.78%
30	19	0.895	0.867	-0.03	-3.21%	4.57%
30	20	0.896	0.864	-0.03	-3.51%	4.98%
31	21	0.894	0.872	-0.02	-2.48%	3.52%
31	22	0.893	0.872	-0.02	-2.40%	3.40%
31	23	0.894	0.873	-0.02	-2.37%	3.37%
31	24	0.894	0.872	-0.02	-2.52%	3.57%
31	25	0.895	0.874	-0.02	-2.42%	3.44%
31	26	0.896	0.873	-0.02	-2.54%	3.62%
50	27	0.892	0.827	-0.06	-7.22%	10.22%
50	28	0.898	0.829	-0.07	-7.62%	10.86%
50	29	0.898	0.834	-0.06	-7.08%	10.09%
50	30	0.896	0.832	-0.06	-7.20%	10.24%
50	31	0.898	0.834	-0.06	-7.09%	10.10%
Max		0.901	0.899	0.00	0.11%	10.86%
Average		0.896	0.873	-0.02	-2.57%	3.66%
Min		0.892	0.827	-0.06	-7.62%	0.06%
Std Dev		0.002	0.020	0.02	2.18%	3.09%




TID Report

SN54SC6T07-SEP

VIH_2P75V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.28					
Min Limit	0.65					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.022	1.021	0.00	-0.11%	0.17%
0	2	1.017	1.019	0.00	0.13%	0.22%
0	3	1.019	1.019	0.00	-0.06%	0.10%
0	4	1.016	1.016	0.00	-0.02%	0.02%
10	5	1.019	1.011	-0.01	-0.75%	1.21%
10	6	1.019	1.013	-0.01	-0.60%	0.97%
10	7	1.017	1.012	0.00	-0.43%	0.70%
10	8	1.019	1.012	-0.01	-0.68%	1.10%
10	9	1.020	1.011	-0.01	-0.81%	1.31%
20	10	1.016	1.001	-0.01	-1.46%	2.36%
20	11	1.015	1.002	-0.01	-1.35%	2.18%
20	12	1.016	1.000	-0.02	-1.56%	2.52%
20	13	1.015	1.000	-0.02	-1.49%	2.40%
20	14	1.017	1.002	-0.02	-1.51%	2.43%
30	15	1.015	0.987	-0.03	-2.74%	4.41%
30	16	1.015	0.988	-0.03	-2.63%	4.24%
30	17	1.014	0.989	-0.03	-2.48%	3.98%
30	18	1.014	0.988	-0.03	-2.58%	4.14%
30	19	1.015	0.990	-0.02	-2.46%	3.97%
30	20	1.015	0.989	-0.03	-2.54%	4.10%
31	21	1.015	0.996	-0.02	-1.90%	3.06%
31	22	1.015	0.995	-0.02	-1.93%	3.11%
31	23	1.014	0.996	-0.02	-1.80%	2.89%
31	24	1.014	0.996	-0.02	-1.72%	2.77%
31	25	1.015	0.997	-0.02	-1.78%	2.87%
31	26	1.015	0.995	-0.02	-1.95%	3.13%
50	27	1.014	0.960	-0.05	-5.36%	8.63%
50	28	1.018	0.963	-0.06	-5.43%	8.77%
50	29	1.019	0.965	-0.05	-5.32%	8.61%
50	30	1.018	0.964	-0.05	-5.31%	8.58%
50	31	1.018	0.966	-0.05	-5.08%	8.22%
Max		1.022	1.021	0.00	0.13%	8.77%
Average		1.016	0.997	-0.02	-1.95%	3.17%
Min		1.014	0.960	-0.05	-5.43%	0.02%
Std Dev		0.002	0.017	0.01	1.59%	2.55%






VIH_2P75V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.28					
Min Limit	0.65					
krad	0	10	20	30	31	50
LL	0.65	0.65	0.65	0.65	0.65	0.65
Min	1.02	1.01	1.00	0.99	0.99	0.96
Average	1.02	1.01	1.00	0.99	0.99	0.98
Max	1.02	1.02	1.01	1.00	1.00	1.00
UL	1.28	1.28	1.28	1.28	1.28	1.28



TID Report

SN54SC6T07-SEP


VIH_2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.1					
Min Limit	0.5					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.830	0.831	0.00	0.06%	0.08%
0	2	0.828	0.828	0.00	-0.08%	0.11%
0	3	0.830	0.829	0.00	-0.06%	0.08%
0	4	0.827	0.828	0.00	0.16%	0.22%
10	5	0.828	0.821	-0.01	-0.85%	1.17%
10	6	0.829	0.823	-0.01	-0.67%	0.93%
10	7	0.828	0.821	-0.01	-0.93%	1.28%
10	8	0.827	0.820	-0.01	-0.80%	1.11%
10	9	0.828	0.821	-0.01	-0.86%	1.19%
20	10	0.827	0.810	-0.02	-2.12%	2.92%
20	11	0.825	0.806	-0.02	-2.26%	3.10%
20	12	0.823	0.807	-0.02	-1.99%	2.72%
20	13	0.825	0.807	-0.02	-2.16%	2.96%
20	14	0.826	0.810	-0.02	-1.91%	2.63%
30	15	0.824	0.791	-0.03	-3.97%	5.45%
30	16	0.824	0.791	-0.03	-4.01%	5.51%
30	17	0.825	0.790	-0.04	-4.26%	5.86%
30	18	0.825	0.792	-0.03	-3.99%	5.49%
30	19	0.826	0.794	-0.03	-3.85%	5.29%
30	20	0.826	0.792	-0.03	-4.04%	5.55%
31	21	0.824	0.800	-0.02	-2.83%	3.88%
31	22	0.824	0.798	-0.03	-3.07%	4.21%
31	23	0.825	0.800	-0.02	-2.98%	4.10%
31	24	0.825	0.800	-0.02	-3.00%	4.13%
31	25	0.826	0.803	-0.02	-2.82%	3.88%
31	26	0.826	0.802	-0.02	-2.89%	3.98%
50	27	0.824	0.746	-0.08	-9.50%	13.05%
50	28	0.829	0.750	-0.08	-9.46%	13.07%
50	29	0.828	0.754	-0.07	-8.98%	12.39%
50	30	0.827	0.750	-0.08	-9.36%	12.91%
50	31	0.829	0.755	-0.07	-8.90%	12.30%
Max		0.830	0.831	0.00	0.16%	13.07%
Average		0.826	0.801	-0.03	-3.12%	4.31%
Min		0.823	0.746	-0.08	-9.50%	0.08%
Std Dev		0.002	0.024	0.02	2.82%	3.86%




TID Report

SN54SC6T07-SEP

VIH_3P6V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.45					
Min Limit	0.75					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.206	1.205	0.00	-0.05%	0.08%
0	2	1.201	1.203	0.00	0.17%	0.29%
0	3	1.204	1.203	0.00	-0.06%	0.10%
0	4	1.201	1.201	0.00	-0.05%	0.09%
10	5	1.203	1.196	-0.01	-0.60%	1.03%
10	6	1.205	1.198	-0.01	-0.56%	0.96%
10	7	1.200	1.195	-0.01	-0.43%	0.74%
10	8	1.204	1.200	0.00	-0.37%	0.63%
10	9	1.202	1.196	-0.01	-0.57%	0.97%
20	10	1.198	1.185	-0.01	-1.05%	1.79%
20	11	1.202	1.187	-0.02	-1.29%	2.21%
20	12	1.201	1.186	-0.02	-1.32%	2.26%
20	13	1.199	1.186	-0.01	-1.05%	1.80%
20	14	1.202	1.188	-0.01	-1.19%	2.04%
30	15	1.199	1.176	-0.02	-1.94%	3.32%
30	16	1.198	1.176	-0.02	-1.79%	3.07%
30	17	1.203	1.177	-0.03	-2.17%	3.73%
30	18	1.199	1.175	-0.02	-2.03%	3.48%
30	19	1.201	1.178	-0.02	-1.95%	3.35%
30	20	1.199	1.174	-0.02	-2.07%	3.54%
31	21	1.199	1.182	-0.02	-1.40%	2.39%
31	22	1.198	1.183	-0.02	-1.25%	2.14%
31	23	1.203	1.183	-0.02	-1.66%	2.86%
31	24	1.199	1.183	-0.02	-1.40%	2.40%
31	25	1.201	1.182	-0.02	-1.57%	2.70%
31	26	1.199	1.180	-0.02	-1.52%	2.59%
50	27	1.198	1.153	-0.04	-3.69%	6.32%
50	28	1.202	1.157	-0.04	-3.72%	6.39%
50	29	1.203	1.158	-0.04	-3.74%	6.42%
50	30	1.203	1.156	-0.05	-3.87%	6.65%
50	31	1.204	1.160	-0.04	-3.66%	6.29%
Max		1.206	1.205	0.00	0.17%	6.65%
Average		1.201	1.183	-0.02	-1.47%	2.55%
Min		1.198	1.153	-0.04	-3.87%	0.08%
Std Dev		0.002	0.014	0.01	1.12%	1.90%






VIH_3P6V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.45					
Min Limit	0.75					
krad	0	10	20	30	31	50
LL	0.75	0.75	0.75	0.75	0.75	0.75
Min	1.20	1.20	1.19	1.18	1.17	1.15
Average	1.20	1.20	1.19	1.18	1.18	1.17
Max	1.21	1.20	1.20	1.19	1.18	1.18
UL	1.45	1.45	1.45	1.45	1.45	1.45



TID Report

SN54SC6T07-SEP




VIH_3V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.45					
Min Limit	0.75					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.079	1.078	0.00	-0.03%	0.05%
0	2	1.073	1.073	0.00	-0.01%	0.01%
0	3	1.077	1.074	0.00	-0.22%	0.34%
0	4	1.074	1.075	0.00	0.08%	0.12%
10	5	1.076	1.070	-0.01	-0.56%	0.86%
10	6	1.076	1.070	-0.01	-0.61%	0.94%
10	7	1.074	1.070	0.00	-0.37%	0.57%
10	8	1.077	1.070	-0.01	-0.70%	1.08%
10	9	1.075	1.068	-0.01	-0.63%	0.97%
20	10	1.072	1.056	-0.02	-1.45%	2.22%
20	11	1.072	1.059	-0.01	-1.25%	1.91%
20	12	1.073	1.058	-0.01	-1.36%	2.09%
20	13	1.072	1.058	-0.01	-1.32%	2.02%
20	14	1.072	1.058	-0.01	-1.28%	1.96%
30	15	1.072	1.047	-0.02	-2.28%	3.49%
30	16	1.072	1.046	-0.03	-2.38%	3.65%
30	17	1.073	1.047	-0.03	-2.47%	3.79%
30	18	1.071	1.046	-0.02	-2.31%	3.53%
30	19	1.074	1.049	-0.02	-2.29%	3.51%
30	20	1.072	1.046	-0.03	-2.47%	3.78%
31	21	1.072	1.055	-0.02	-1.55%	2.37%
31	22	1.072	1.051	-0.02	-1.91%	2.92%
31	23	1.073	1.054	-0.02	-1.82%	2.78%
31	24	1.071	1.052	-0.02	-1.74%	2.66%
31	25	1.074	1.056	-0.02	-1.69%	2.59%
31	26	1.072	1.053	-0.02	-1.83%	2.80%
50	27	1.070	1.020	-0.05	-4.69%	7.17%
50	28	1.077	1.025	-0.05	-4.77%	7.34%
50	29	1.075	1.027	-0.05	-4.46%	6.84%
50	30	1.075	1.023	-0.05	-4.77%	7.33%
50	31	1.076	1.027	-0.05	-4.55%	6.99%
Max		1.079	1.078	0.00	0.08%	7.34%
Average		1.074	1.055	-0.02	-1.77%	2.72%
Min		1.070	1.020	-0.05	-4.77%	0.01%
Std Dev		0.002	0.016	0.01	1.39%	2.12%



TID Report

SN54SC6T07-SEP




VIH_4P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	2					
Min Limit	0.85					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.383	1.383	0.00	0.02%	0.02%
0	2	1.378	1.379	0.00	0.08%	0.09%
0	3	1.383	1.381	0.00	-0.10%	0.12%
0	4	1.381	1.380	0.00	-0.13%	0.15%
10	5	1.381	1.374	-0.01	-0.49%	0.59%
10	6	1.382	1.375	-0.01	-0.46%	0.56%
10	7	1.381	1.374	-0.01	-0.55%	0.66%
10	8	1.384	1.376	-0.01	-0.61%	0.74%
10	9	1.381	1.377	0.00	-0.28%	0.33%
20	10	1.377	1.363	-0.01	-1.04%	1.24%
20	11	1.380	1.367	-0.01	-0.93%	1.12%
20	12	1.380	1.366	-0.01	-1.02%	1.22%
20	13	1.377	1.364	-0.01	-0.93%	1.11%
20	14	1.379	1.366	-0.01	-0.93%	1.12%
30	15	1.379	1.355	-0.02	-1.74%	2.09%
30	16	1.378	1.355	-0.02	-1.73%	2.07%
30	17	1.379	1.359	-0.02	-1.50%	1.79%
30	18	1.376	1.352	-0.02	-1.76%	2.11%
30	19	1.380	1.356	-0.02	-1.78%	2.13%
30	20	1.377	1.354	-0.02	-1.71%	2.05%
31	21	1.379	1.362	-0.02	-1.26%	1.51%
31	22	1.378	1.358	-0.02	-1.45%	1.74%
31	23	1.379	1.363	-0.02	-1.15%	1.38%
31	24	1.376	1.358	-0.02	-1.31%	1.57%
31	25	1.380	1.363	-0.02	-1.22%	1.47%
31	26	1.377	1.360	-0.02	-1.26%	1.51%
50	27	1.379	1.336	-0.04	-3.07%	3.68%
50	28	1.383	1.341	-0.04	-3.06%	3.67%
50	29	1.383	1.341	-0.04	-3.10%	3.72%
50	30	1.380	1.339	-0.04	-2.98%	3.57%
50	31	1.382	1.341	-0.04	-2.95%	3.54%
Max		1.384	1.383	0.00	0.08%	3.72%
Average		1.380	1.363	-0.02	-1.25%	1.50%
Min		1.376	1.336	-0.04	-3.10%	0.02%
Std Dev		0.002	0.013	0.01	0.90%	1.07%



TID Report

SN54SC6T07-SEP




VIH_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	2					
Min Limit	0.85					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.568	1.570	0.00	0.08%	0.11%
0	2	1.565	1.565	0.00	0.03%	0.03%
0	3	1.566	1.566	0.00	0.01%	0.01%
0	4	1.564	1.565	0.00	0.05%	0.07%
10	5	1.567	1.557	-0.01	-0.60%	0.82%
10	6	1.567	1.560	-0.01	-0.44%	0.60%
10	7	1.564	1.557	-0.01	-0.43%	0.59%
10	8	1.568	1.561	-0.01	-0.45%	0.62%
10	9	1.568	1.561	-0.01	-0.44%	0.61%
20	10	1.559	1.544	-0.01	-0.93%	1.26%
20	11	1.566	1.550	-0.02	-0.98%	1.34%
20	12	1.563	1.549	-0.01	-0.91%	1.24%
20	13	1.559	1.547	-0.01	-0.77%	1.04%
20	14	1.561	1.546	-0.02	-1.00%	1.36%
30	15	1.563	1.542	-0.02	-1.38%	1.88%
30	16	1.563	1.539	-0.02	-1.58%	2.15%
30	17	1.565	1.542	-0.02	-1.45%	1.97%
30	18	1.561	1.536	-0.02	-1.57%	2.13%
30	19	1.564	1.542	-0.02	-1.41%	1.91%
30	20	1.561	1.538	-0.02	-1.49%	2.02%
31	21	1.563	1.546	-0.02	-1.10%	1.50%
31	22	1.563	1.545	-0.02	-1.18%	1.60%
31	23	1.565	1.549	-0.02	-0.99%	1.34%
31	24	1.561	1.543	-0.02	-1.13%	1.53%
31	25	1.564	1.547	-0.02	-1.04%	1.41%
31	26	1.561	1.545	-0.02	-1.03%	1.39%
50	27	1.563	1.522	-0.04	-2.61%	3.55%
50	28	1.566	1.524	-0.04	-2.69%	3.66%
50	29	1.567	1.527	-0.04	-2.54%	3.46%
50	30	1.562	1.521	-0.04	-2.61%	3.55%
50	31	1.567	1.527	-0.04	-2.58%	3.52%
Max		1.568	1.570	0.00	0.08%	3.66%
Average		1.564	1.547	-0.02	-1.09%	1.49%
Min		1.559	1.521	-0.04	-2.69%	0.01%
Std Dev		0.003	0.013	0.01	0.78%	1.03%



TID Report

SN54SC6T07-SEP




VIL_1P2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.75					
Min Limit	0.18					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.549	0.549	0.00	0.02%	0.02%
0	2	0.547	0.547	0.00	-0.02%	0.02%
0	3	0.546	0.546	0.00	-0.01%	0.01%
0	4	0.545	0.545	0.00	-0.02%	0.02%
10	5	0.545	0.537	-0.01	-1.48%	1.42%
10	6	0.547	0.539	-0.01	-1.33%	1.28%
10	7	0.549	0.540	-0.01	-1.57%	1.52%
10	8	0.545	0.537	-0.01	-1.50%	1.43%
10	9	0.546	0.538	-0.01	-1.44%	1.38%
20	10	0.547	0.520	-0.03	-4.94%	4.75%
20	11	0.543	0.515	-0.03	-5.33%	5.08%
20	12	0.542	0.513	-0.03	-5.26%	5.00%
20	13	0.545	0.514	-0.03	-5.73%	5.48%
20	14	0.545	0.523	-0.02	-3.98%	3.81%
30	15	0.542	0.466	-0.08	-14.01%	13.32%
30	16	0.543	0.462	-0.08	-14.94%	14.24%
30	17	0.544	0.464	-0.08	-14.66%	13.99%
30	18	0.544	0.468	-0.08	-13.98%	13.34%
30	19	0.544	0.471	-0.07	-13.31%	12.70%
30	20	0.545	0.475	-0.07	-12.92%	12.35%
31	21	0.542	0.489	-0.05	-9.75%	9.27%
31	22	0.543	0.486	-0.06	-10.60%	10.10%
31	23	0.544	0.488	-0.06	-10.32%	9.85%
31	24	0.544	0.487	-0.06	-10.52%	10.04%
31	25	0.544	0.493	-0.05	-9.30%	8.87%
31	26	0.545	0.496	-0.05	-9.05%	8.65%
50	27	0.543	0.345	-0.20	-36.35%	34.61%
50	28	0.548	0.356	-0.19	-35.01%	33.66%
50	29	0.546	0.360	-0.19	-34.15%	32.73%
50	30	0.548	0.343	-0.20	-37.37%	35.93%
50	31	0.546	0.370	-0.18	-32.20%	30.83%
Max		0.549	0.549	0.00	0.02%	35.93%
Average		0.545	0.487	-0.06	-10.63%	10.16%
Min		0.542	0.343	-0.20	-37.37%	0.01%
Std Dev		0.002	0.061	0.06	11.18%	10.72%



TID Report

SN54SC6T07-SEP




VIL_1P3V						
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.587	0.587	0.00	0.00%	0.00%
0	2	0.586	0.586	0.00	-0.01%	0.01%
0	3	0.586	0.585	0.00	-0.07%	0.07%
0	4	0.584	0.584	0.00	-0.02%	0.02%
10	5	0.584	0.576	-0.01	-1.28%	1.31%
10	6	0.585	0.578	-0.01	-1.15%	1.18%
10	7	0.588	0.579	-0.01	-1.50%	1.54%
10	8	0.583	0.575	-0.01	-1.35%	1.38%
10	9	0.585	0.577	-0.01	-1.37%	1.41%
20	10	0.586	0.563	-0.02	-3.98%	4.09%
20	11	0.582	0.556	-0.03	-4.45%	4.54%
20	12	0.580	0.556	-0.02	-4.12%	4.19%
20	13	0.583	0.557	-0.03	-4.57%	4.68%
20	14	0.583	0.564	-0.02	-3.35%	3.43%
30	15	0.580	0.519	-0.06	-10.57%	10.77%
30	16	0.581	0.514	-0.07	-11.52%	11.75%
30	17	0.582	0.515	-0.07	-11.49%	11.74%
30	18	0.583	0.520	-0.06	-10.80%	11.04%
30	19	0.583	0.522	-0.06	-10.33%	10.56%
30	20	0.584	0.525	-0.06	-10.06%	10.31%
31	21	0.580	0.537	-0.04	-7.40%	7.53%
31	22	0.581	0.534	-0.05	-8.15%	8.31%
31	23	0.582	0.536	-0.05	-7.92%	8.09%
31	24	0.583	0.535	-0.05	-8.17%	8.35%
31	25	0.583	0.540	-0.04	-7.23%	7.39%
31	26	0.584	0.542	-0.04	-7.10%	7.27%
50	27	0.581	0.406	-0.18	-30.22%	30.81%
50	28	0.586	0.418	-0.17	-28.75%	29.57%
50	29	0.585	0.423	-0.16	-27.69%	28.42%
50	30	0.586	0.408	-0.18	-30.45%	31.31%
50	31	0.585	0.431	-0.15	-26.29%	26.97%
Max		0.588	0.587	0.00	0.00%	31.31%
Average		0.584	0.534	-0.05	-8.50%	8.70%
Min		0.580	0.406	-0.17	-30.45%	0.00%
Std Dev		0.002	0.053	0.05	9.12%	9.35%



TID Report

SN54SC6T07-SEP




VIL_1P65V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1					
Min Limit	0.5					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.710	0.710	0.00	0.00%	0.00%
0	2	0.709	0.709	0.00	0.04%	0.05%
0	3	0.710	0.709	0.00	-0.07%	0.10%
0	4	0.708	0.707	0.00	-0.07%	0.10%
10	5	0.707	0.700	-0.01	-1.01%	1.43%
10	6	0.708	0.702	-0.01	-0.97%	1.37%
10	7	0.710	0.703	-0.01	-1.01%	1.43%
10	8	0.706	0.699	-0.01	-1.02%	1.45%
10	9	0.709	0.700	-0.01	-1.25%	1.77%
20	10	0.708	0.690	-0.02	-2.55%	3.61%
20	11	0.705	0.683	-0.02	-3.04%	4.28%
20	12	0.703	0.685	-0.02	-2.57%	3.61%
20	13	0.706	0.685	-0.02	-3.00%	4.24%
20	14	0.706	0.690	-0.02	-2.31%	3.26%
30	15	0.704	0.664	-0.04	-5.66%	7.97%
30	16	0.704	0.660	-0.04	-6.20%	8.73%
30	17	0.705	0.660	-0.04	-6.37%	8.99%
30	18	0.705	0.662	-0.04	-6.09%	8.59%
30	19	0.705	0.665	-0.04	-5.72%	8.07%
30	20	0.707	0.666	-0.04	-5.69%	8.05%
31	21	0.704	0.675	-0.03	-4.10%	5.76%
31	22	0.704	0.673	-0.03	-4.38%	6.16%
31	23	0.705	0.674	-0.03	-4.45%	6.27%
31	24	0.705	0.674	-0.03	-4.46%	6.29%
31	25	0.705	0.676	-0.03	-4.17%	5.88%
31	26	0.707	0.677	-0.03	-4.16%	5.89%
50	27	0.704	0.588	-0.12	-16.50%	23.23%
50	28	0.710	0.598	-0.11	-15.67%	22.23%
50	29	0.708	0.603	-0.11	-14.89%	21.09%
50	30	0.709	0.593	-0.12	-16.35%	23.19%
50	31	0.709	0.606	-0.10	-14.52%	20.58%
Max		0.710	0.710	0.00	0.04%	23.23%
Average		0.707	0.673	-0.03	-4.79%	6.77%
Min		0.703	0.588	-0.12	-16.50%	0.00%
Std Dev		0.002	0.035	0.03	4.86%	6.87%



TID Report

SN54SC6T07-SEP




VIL_2P25V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.25					
Min Limit	0.65					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.880	0.880	0.00	0.00%	0.01%
0	2	0.878	0.878	0.00	0.06%	0.09%
0	3	0.880	0.878	0.00	-0.21%	0.30%
0	4	0.879	0.878	0.00	-0.12%	0.18%
10	5	0.877	0.870	-0.01	-0.76%	1.11%
10	6	0.879	0.873	-0.01	-0.68%	0.99%
10	7	0.878	0.872	-0.01	-0.65%	0.95%
10	8	0.877	0.870	-0.01	-0.77%	1.13%
10	9	0.878	0.872	-0.01	-0.74%	1.08%
20	10	0.876	0.861	-0.01	-1.64%	2.39%
20	11	0.874	0.858	-0.02	-1.84%	2.68%
20	12	0.873	0.858	-0.01	-1.71%	2.49%
20	13	0.876	0.859	-0.02	-1.89%	2.75%
20	14	0.876	0.864	-0.01	-1.45%	2.11%
30	15	0.875	0.846	-0.03	-3.34%	4.87%
30	16	0.875	0.844	-0.03	-3.55%	5.17%
30	17	0.874	0.845	-0.03	-3.33%	4.84%
30	18	0.875	0.845	-0.03	-3.43%	5.00%
30	19	0.875	0.846	-0.03	-3.33%	4.86%
30	20	0.876	0.849	-0.03	-3.10%	4.53%
31	21	0.875	0.853	-0.02	-2.47%	3.60%
31	22	0.875	0.853	-0.02	-2.47%	3.60%
31	23	0.874	0.853	-0.02	-2.35%	3.42%
31	24	0.875	0.854	-0.02	-2.43%	3.54%
31	25	0.875	0.854	-0.02	-2.43%	3.54%
31	26	0.876	0.856	-0.02	-2.29%	3.34%
50	27	0.873	0.802	-0.07	-8.13%	11.83%
50	28	0.880	0.813	-0.07	-7.59%	11.14%
50	29	0.878	0.815	-0.06	-7.18%	10.51%
50	30	0.878	0.808	-0.07	-7.94%	11.62%
50	31	0.879	0.817	-0.06	-7.09%	10.38%
Max		0.880	0.880	0.00	0.06%	11.83%
Average		0.876	0.854	-0.02	-2.59%	3.79%
Min		0.873	0.802	-0.07	-8.13%	0.01%
Std Dev		0.002	0.021	0.02	2.32%	3.39%



TID Report

SN54SC6T07-SEP




VIL_2P75V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.25					
Min Limit	0.65					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.995	0.996	0.00	0.02%	0.03%
0	2	0.992	0.992	0.00	0.00%	0.01%
0	3	0.994	0.994	0.00	-0.07%	0.12%
0	4	0.995	0.995	0.00	-0.03%	0.05%
10	5	0.992	0.988	0.00	-0.49%	0.82%
10	6	0.995	0.991	0.00	-0.41%	0.68%
10	7	0.993	0.988	-0.01	-0.51%	0.84%
10	8	0.993	0.988	-0.01	-0.56%	0.93%
10	9	0.994	0.988	-0.01	-0.61%	1.00%
20	10	0.991	0.977	-0.01	-1.34%	2.22%
20	11	0.991	0.975	-0.02	-1.61%	2.67%
20	12	0.990	0.976	-0.01	-1.34%	2.22%
20	13	0.991	0.977	-0.01	-1.44%	2.38%
20	14	0.993	0.979	-0.01	-1.47%	2.43%
30	15	0.992	0.965	-0.03	-2.72%	4.50%
30	16	0.989	0.964	-0.03	-2.53%	4.17%
30	17	0.990	0.964	-0.03	-2.69%	4.45%
30	18	0.991	0.964	-0.03	-2.73%	4.51%
30	19	0.992	0.965	-0.03	-2.64%	4.37%
30	20	0.992	0.967	-0.02	-2.44%	4.04%
31	21	0.992	0.972	-0.02	-2.01%	3.33%
31	22	0.989	0.970	-0.02	-2.01%	3.31%
31	23	0.990	0.973	-0.02	-1.75%	2.88%
31	24	0.991	0.971	-0.02	-2.01%	3.32%
31	25	0.992	0.972	-0.02	-1.98%	3.27%
31	26	0.992	0.973	-0.02	-1.84%	3.04%
50	27	0.990	0.932	-0.06	-5.93%	9.79%
50	28	0.996	0.943	-0.05	-5.38%	8.94%
50	29	0.995	0.943	-0.05	-5.20%	8.61%
50	30	0.993	0.938	-0.06	-5.55%	9.19%
50	31	0.994	0.942	-0.05	-5.24%	8.68%
Max		0.996	0.996	0.00	0.02%	9.79%
Average		0.992	0.973	-0.02	-1.98%	3.27%
Min		0.989	0.932	-0.06	-5.93%	0.01%
Std Dev		0.002	0.017	0.01	1.67%	2.76%



TID Report

SN54SC6T07-SEP




VIL_2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1					
Min Limit	0.5					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.815	0.815	0.00	0.00%	0.01%
0	2	0.813	0.813	0.00	0.00%	0.00%
0	3	0.814	0.814	0.00	-0.11%	0.19%
0	4	0.813	0.812	0.00	-0.12%	0.19%
10	5	0.813	0.805	-0.01	-0.88%	1.44%
10	6	0.814	0.807	-0.01	-0.76%	1.24%
10	7	0.813	0.808	-0.01	-0.66%	1.08%
10	8	0.811	0.804	-0.01	-0.83%	1.34%
10	9	0.813	0.806	-0.01	-0.88%	1.42%
20	10	0.812	0.797	-0.02	-1.86%	3.01%
20	11	0.809	0.791	-0.02	-2.24%	3.63%
20	12	0.808	0.792	-0.02	-2.01%	3.24%
20	13	0.810	0.792	-0.02	-2.27%	3.68%
20	14	0.811	0.797	-0.01	-1.78%	2.89%
30	15	0.808	0.777	-0.03	-3.92%	6.34%
30	16	0.808	0.776	-0.03	-4.01%	6.48%
30	17	0.810	0.776	-0.03	-4.24%	6.87%
30	18	0.809	0.776	-0.03	-4.13%	6.69%
30	19	0.810	0.778	-0.03	-3.93%	6.37%
30	20	0.811	0.780	-0.03	-3.81%	6.17%
31	21	0.808	0.786	-0.02	-2.79%	4.51%
31	22	0.808	0.784	-0.02	-2.99%	4.83%
31	23	0.810	0.785	-0.03	-3.12%	5.05%
31	24	0.809	0.785	-0.02	-2.97%	4.81%
31	25	0.810	0.787	-0.02	-2.93%	4.76%
31	26	0.811	0.788	-0.02	-2.82%	4.57%
50	27	0.809	0.724	-0.08	-10.45%	16.90%
50	28	0.814	0.735	-0.08	-9.70%	15.79%
50	29	0.814	0.736	-0.08	-9.49%	15.44%
50	30	0.814	0.732	-0.08	-10.09%	16.43%
50	31	0.813	0.738	-0.07	-9.23%	15.00%
Max		0.815	0.815	0.00	0.00%	16.90%
Average		0.811	0.785	-0.03	-3.19%	5.18%
Min		0.808	0.724	-0.08	-10.45%	0.00%
Std Dev		0.002	0.025	0.02	3.00%	4.88%



TID Report

SN54SC6T07-SEP


VIL_3P6V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.35					
Min Limit	0.75					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.171	1.170	0.00	-0.01%	0.02%
0	2	1.167	1.167	0.00	-0.01%	0.02%
0	3	1.168	1.167	0.00	-0.03%	0.06%
0	4	1.169	1.169	0.00	0.03%	0.06%
10	5	1.167	1.161	-0.01	-0.57%	1.10%
10	6	1.170	1.163	-0.01	-0.55%	1.07%
10	7	1.167	1.162	0.00	-0.38%	0.73%
10	8	1.169	1.163	-0.01	-0.51%	1.00%
10	9	1.169	1.164	0.00	-0.42%	0.82%
20	10	1.164	1.152	-0.01	-1.07%	2.07%
20	11	1.166	1.152	-0.01	-1.20%	2.33%
20	12	1.164	1.152	-0.01	-1.03%	2.00%
20	13	1.165	1.152	-0.01	-1.12%	2.17%
20	14	1.166	1.153	-0.01	-1.13%	2.20%
30	15	1.166	1.142	-0.02	-2.06%	4.00%
30	16	1.164	1.142	-0.02	-1.85%	3.60%
30	17	1.166	1.142	-0.02	-2.09%	4.05%
30	18	1.163	1.142	-0.02	-1.86%	3.60%
30	19	1.165	1.142	-0.02	-1.95%	3.79%
30	20	1.165	1.142	-0.02	-1.92%	3.72%
31	21	1.166	1.149	-0.02	-1.50%	2.91%
31	22	1.164	1.148	-0.02	-1.30%	2.53%
31	23	1.166	1.150	-0.02	-1.39%	2.70%
31	24	1.163	1.147	-0.02	-1.36%	2.63%
31	25	1.165	1.148	-0.02	-1.38%	2.67%
31	26	1.165	1.148	-0.02	-1.40%	2.72%
50	27	1.164	1.117	-0.05	-4.05%	7.86%
50	28	1.171	1.124	-0.05	-3.97%	7.75%
50	29	1.170	1.126	-0.04	-3.76%	7.32%
50	30	1.167	1.122	-0.05	-3.90%	7.58%
50	31	1.169	1.125	-0.04	-3.75%	7.30%
Max		1.171	1.170	0.00	0.03%	7.86%
Average		1.166	1.149	-0.02	-1.46%	2.84%
Min		1.163	1.117	-0.05	-4.05%	0.02%
Std Dev		0.002	0.014	0.01	1.17%	2.27%




TID Report

SN54SC6T07-SEP

VIL_3V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.35					
Min Limit	0.75					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.050	1.049	0.00	-0.09%	0.16%
0	2	1.047	1.046	0.00	-0.04%	0.07%
0	3	1.047	1.046	0.00	-0.10%	0.17%
0	4	1.047	1.047	0.00	0.07%	0.12%
10	5	1.046	1.040	-0.01	-0.58%	1.00%
10	6	1.049	1.042	-0.01	-0.59%	1.03%
10	7	1.047	1.042	-0.01	-0.53%	0.93%
10	8	1.047	1.041	-0.01	-0.57%	1.00%
10	9	1.050	1.042	-0.01	-0.68%	1.20%
20	10	1.045	1.033	-0.01	-1.20%	2.09%
20	11	1.046	1.031	-0.01	-1.41%	2.46%
20	12	1.043	1.030	-0.01	-1.25%	2.17%
20	13	1.045	1.030	-0.01	-1.38%	2.41%
20	14	1.046	1.032	-0.01	-1.34%	2.34%
30	15	1.045	1.020	-0.02	-2.39%	4.17%
30	16	1.043	1.019	-0.02	-2.34%	4.07%
30	17	1.046	1.021	-0.03	-2.40%	4.18%
30	18	1.044	1.019	-0.03	-2.41%	4.19%
30	19	1.044	1.020	-0.02	-2.30%	4.01%
30	20	1.046	1.022	-0.02	-2.26%	3.95%
31	21	1.045	1.027	-0.02	-1.71%	2.99%
31	22	1.043	1.026	-0.02	-1.66%	2.88%
31	23	1.046	1.028	-0.02	-1.73%	3.02%
31	24	1.044	1.025	-0.02	-1.82%	3.17%
31	25	1.044	1.026	-0.02	-1.72%	3.00%
31	26	1.046	1.028	-0.02	-1.70%	2.96%
50	27	1.043	0.989	-0.05	-5.18%	9.01%
50	28	1.049	0.998	-0.05	-4.93%	8.62%
50	29	1.048	1.000	-0.05	-4.66%	8.14%
50	30	1.046	0.996	-0.05	-4.78%	8.34%
50	31	1.048	1.000	-0.05	-4.59%	8.03%
Max		1.050	1.049	0.00	0.07%	9.01%
Average		1.046	1.027	-0.02	-1.79%	3.13%
Min		1.043	0.989	-0.05	-5.18%	0.07%
Std Dev		0.002	0.016	0.01	1.45%	2.52%






VIL_3V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.35					
Min Limit	0.75					
krad	0	10	20	30	31	50
LL	0.75	0.75	0.75	0.75	0.75	0.75
Min	1.05	1.04	1.03	1.02	1.02	0.99
Average	1.05	1.04	1.03	1.02	1.02	1.01
Max	1.05	1.05	1.04	1.03	1.03	1.03
UL	1.35	1.35	1.35	1.35	1.35	1.35



TID Report

SN54SC6T07-SEP




VIL_4P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.85					
Min Limit	0.85					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.334	1.334	0.00	0.00%	0.00%
0	2	1.330	1.331	0.00	0.10%	0.13%
0	3	1.331	1.331	0.00	0.00%	0.00%
0	4	1.332	1.331	0.00	-0.04%	0.05%
10	5	1.331	1.326	-0.01	-0.44%	0.58%
10	6	1.334	1.327	-0.01	-0.54%	0.72%
10	7	1.330	1.325	-0.01	-0.38%	0.50%
10	8	1.333	1.327	-0.01	-0.47%	0.62%
10	9	1.333	1.327	-0.01	-0.47%	0.63%
20	10	1.326	1.312	-0.01	-1.10%	1.46%
20	11	1.331	1.316	-0.01	-1.11%	1.47%
20	12	1.330	1.316	-0.01	-1.03%	1.37%
20	13	1.328	1.316	-0.01	-0.89%	1.18%
20	14	1.331	1.316	-0.02	-1.15%	1.53%
30	15	1.332	1.308	-0.02	-1.77%	2.35%
30	16	1.327	1.307	-0.02	-1.49%	1.98%
30	17	1.331	1.308	-0.02	-1.70%	2.26%
30	18	1.325	1.306	-0.02	-1.48%	1.96%
30	19	1.328	1.307	-0.02	-1.60%	2.12%
30	20	1.328	1.307	-0.02	-1.60%	2.13%
31	21	1.332	1.313	-0.02	-1.39%	1.85%
31	22	1.327	1.311	-0.02	-1.16%	1.53%
31	23	1.331	1.313	-0.02	-1.30%	1.73%
31	24	1.325	1.311	-0.01	-1.12%	1.49%
31	25	1.328	1.312	-0.02	-1.23%	1.63%
31	26	1.328	1.313	-0.01	-1.13%	1.50%
50	27	1.328	1.283	-0.04	-3.36%	4.47%
50	28	1.332	1.290	-0.04	-3.16%	4.21%
50	29	1.333	1.293	-0.04	-2.99%	3.99%
50	30	1.328	1.289	-0.04	-2.99%	3.97%
50	31	1.332	1.292	-0.04	-3.02%	4.02%
Max		1.334	1.334	0.00	0.10%	4.47%
Average		1.330	1.313	-0.02	-1.23%	1.65%
Min		1.325	1.283	-0.04	-3.36%	0.00%
Std Dev		0.002	0.013	0.01	0.93%	1.22%



TID Report

SN54SC6T07-SEP




VIL_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	1.85					
Min Limit	0.85					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	1.495	1.495	0.00	0.00%	0.00%
0	2	1.494	1.494	0.00	0.00%	0.00%
0	3	1.494	1.494	0.00	0.00%	0.00%
0	4	1.495	1.495	0.00	0.00%	0.00%
10	5	1.495	1.494	0.00	-0.01%	0.01%
10	6	1.495	1.494	0.00	-0.01%	0.01%
10	7	1.495	1.494	0.00	0.00%	0.01%
10	8	1.495	1.494	0.00	-0.01%	0.01%
10	9	1.495	1.494	0.00	-0.01%	0.01%
20	10	1.494	1.494	0.00	-0.01%	0.02%
20	11	1.494	1.494	0.00	-0.02%	0.04%
20	12	1.495	1.494	0.00	-0.02%	0.02%
20	13	1.495	1.494	0.00	-0.02%	0.03%
20	14	1.495	1.494	0.00	-0.02%	0.03%
30	15	1.495	1.475	-0.02	-1.31%	1.96%
30	16	1.494	1.475	-0.02	-1.30%	1.94%
30	17	1.494	1.474	-0.02	-1.34%	2.00%
30	18	1.494	1.474	-0.02	-1.34%	2.01%
30	19	1.494	1.472	-0.02	-1.51%	2.25%
30	20	1.495	1.476	-0.02	-1.27%	1.90%
31	21	1.495	1.481	-0.01	-0.93%	1.38%
31	22	1.494	1.480	-0.01	-0.98%	1.46%
31	23	1.494	1.479	-0.02	-1.01%	1.51%
31	24	1.494	1.481	-0.01	-0.87%	1.30%
31	25	1.494	1.477	-0.02	-1.17%	1.75%
31	26	1.495	1.494	0.00	-0.03%	0.04%
50	27	1.494	1.452	-0.04	-2.85%	4.26%
50	28	1.495	1.459	-0.04	-2.36%	3.53%
50	29	1.495	1.460	-0.03	-2.33%	3.48%
50	30	1.495	1.456	-0.04	-2.60%	3.89%
50	31	1.495	1.460	-0.03	-2.34%	3.49%
Max		1.495	1.495	0.00	0.00%	4.26%
Average		1.495	1.483	-0.01	-0.78%	1.16%
Min		1.494	1.452	-0.04	-2.85%	0.00%
Std Dev		0.000	0.013	0.01	0.90%	1.35%



TID Report

SN54SC6T07-SEP




VOL_1MA_1P2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.2					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.048	0.048	0.00	0.05%	0.01%
0	2	0.049	0.049	0.00	0.06%	0.01%
0	3	0.049	0.049	0.00	0.16%	0.03%
0	4	0.049	0.049	0.00	-0.51%	0.08%
10	5	0.049	0.048	0.00	-0.74%	0.12%
10	6	0.049	0.049	0.00	-0.32%	0.05%
10	7	0.049	0.049	0.00	-0.64%	0.10%
10	8	0.049	0.049	0.00	-0.51%	0.08%
10	9	0.049	0.048	0.00	-1.28%	0.21%
20	10	0.049	0.048	0.00	-1.09%	0.18%
20	11	0.049	0.048	0.00	-1.05%	0.17%
20	12	0.049	0.048	0.00	-1.42%	0.23%
20	13	0.049	0.048	0.00	-0.90%	0.15%
20	14	0.049	0.048	0.00	-1.38%	0.23%
30	15	0.049	0.048	0.00	-1.57%	0.25%
30	16	0.049	0.048	0.00	-1.85%	0.30%
30	17	0.049	0.048	0.00	-1.01%	0.16%
30	18	0.048	0.048	0.00	-1.29%	0.21%
30	19	0.048	0.048	0.00	-1.30%	0.21%
30	20	0.049	0.048	0.00	-1.71%	0.28%
31	21	0.049	0.048	0.00	-1.09%	0.18%
31	22	0.049	0.048	0.00	-1.17%	0.19%
31	23	0.049	0.048	0.00	-0.58%	0.09%
31	24	0.048	0.048	0.00	-1.16%	0.19%
31	25	0.048	0.048	0.00	-0.84%	0.14%
31	26	0.049	0.048	0.00	-0.84%	0.14%
50	27	0.049	0.049	0.00	-0.43%	0.07%
50	28	0.049	0.048	0.00	-1.35%	0.22%
50	29	0.049	0.048	0.00	-1.92%	0.31%
50	30	0.048	0.048	0.00	-0.32%	0.05%
50	31	0.048	0.048	0.00	-0.56%	0.09%
Max		0.049	0.049	0.00	0.16%	0.31%
Average		0.049	0.048	0.00	-0.93%	0.15%
Min		0.048	0.048	0.00	-1.92%	0.01%
Std Dev		0.000	0.000	0.00	0.55%	0.08%



TID Report

SN54SC6T07-SEP


VOL_2MA_1P65V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.2					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.058	0.059	0.00	0.49%	0.10%
0	2	0.059	0.059	0.00	0.05%	0.01%
0	3	0.059	0.059	0.00	0.11%	0.02%
0	4	0.059	0.059	0.00	-0.08%	0.02%
10	5	0.059	0.059	0.00	-0.20%	0.04%
10	6	0.059	0.059	0.00	-0.58%	0.11%
10	7	0.059	0.059	0.00	-0.37%	0.07%
10	8	0.059	0.059	0.00	-0.37%	0.07%
10	9	0.059	0.059	0.00	-0.37%	0.07%
20	10	0.059	0.059	0.00	-0.80%	0.16%
20	11	0.060	0.059	0.00	-0.70%	0.14%
20	12	0.060	0.060	0.00	-0.75%	0.15%
20	13	0.060	0.059	0.00	-0.80%	0.16%
20	14	0.059	0.059	0.00	-0.37%	0.07%
30	15	0.060	0.059	0.00	-0.97%	0.19%
30	16	0.060	0.059	0.00	-0.59%	0.12%
30	17	0.060	0.059	0.00	-0.73%	0.15%
30	18	0.059	0.059	0.00	-0.79%	0.16%
30	19	0.059	0.059	0.00	-0.84%	0.17%
30	20	0.060	0.059	0.00	-1.21%	0.24%
31	21	0.060	0.059	0.00	-0.60%	0.12%
31	22	0.060	0.059	0.00	-0.75%	0.15%
31	23	0.060	0.060	0.00	-0.52%	0.10%
31	24	0.059	0.059	0.00	-0.42%	0.08%
31	25	0.059	0.059	0.00	-0.58%	0.11%
31	26	0.060	0.059	0.00	-0.63%	0.13%
50	27	0.060	0.059	0.00	-0.52%	0.10%
50	28	0.059	0.058	0.00	-1.37%	0.27%
50	29	0.059	0.059	0.00	-0.74%	0.15%
50	30	0.059	0.059	0.00	-0.48%	0.09%
50	31	0.059	0.059	0.00	-0.42%	0.08%
Max		0.060	0.060	0.00	0.49%	0.27%
Average		0.059	0.059	0.00	-0.55%	0.12%
Min		0.058	0.058	0.00	-1.37%	0.01%
Std Dev		0.000	0.000	0.00	0.38%	0.06%



TID Report

SN54SC6T07-SEP




VOL_2MA_2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.25					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.048	0.049	0.00	0.28%	0.04%
0	2	0.049	0.049	0.00	0.00%	0.00%
0	3	0.049	0.049	0.00	0.34%	0.05%
0	4	0.049	0.049	0.00	0.17%	0.02%
10	5	0.049	0.049	0.00	-0.45%	0.06%
10	6	0.049	0.049	0.00	-0.46%	0.06%
10	7	0.049	0.049	0.00	-0.46%	0.06%
10	8	0.049	0.049	0.00	-0.26%	0.04%
10	9	0.049	0.049	0.00	-0.64%	0.09%
20	10	0.049	0.049	0.00	-0.57%	0.08%
20	11	0.050	0.049	0.00	-0.63%	0.09%
20	12	0.050	0.050	0.00	-0.38%	0.05%
20	13	0.050	0.050	0.00	-0.46%	0.06%
20	14	0.049	0.049	0.00	-0.37%	0.05%
30	15	0.050	0.049	0.00	-0.59%	0.08%
30	16	0.050	0.049	0.00	-0.44%	0.06%
30	17	0.050	0.049	0.00	-0.38%	0.05%
30	18	0.049	0.049	0.00	-0.57%	0.08%
30	19	0.049	0.049	0.00	-0.82%	0.12%
30	20	0.050	0.049	0.00	-1.20%	0.17%
31	21	0.050	0.050	0.00	-0.15%	0.02%
31	22	0.050	0.050	0.00	-0.20%	0.03%
31	23	0.050	0.050	0.00	0.12%	0.02%
31	24	0.049	0.049	0.00	-0.13%	0.02%
31	25	0.049	0.049	0.00	-0.26%	0.04%
31	26	0.050	0.049	0.00	-0.44%	0.06%
50	27	0.050	0.049	0.00	-0.19%	0.03%
50	28	0.049	0.049	0.00	-0.54%	0.08%
50	29	0.049	0.049	0.00	-0.39%	0.05%
50	30	0.049	0.049	0.00	-0.13%	0.02%
50	31	0.049	0.049	0.00	-0.51%	0.07%
Max		0.050	0.050	0.00	0.34%	0.17%
Average		0.049	0.049	0.00	-0.34%	0.06%
Min		0.048	0.049	0.00	-1.20%	0.00%
Std Dev		0.000	0.000	0.00	0.33%	0.03%



TID Report

SN54SC6T07-SEP




VOL_3MA_2P25V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.2					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.067	0.067	0.00	0.33%	0.07%
0	2	0.067	0.068	0.00	0.37%	0.08%
0	3	0.067	0.067	0.00	0.33%	0.07%
0	4	0.068	0.068	0.00	0.14%	0.03%
10	5	0.067	0.067	0.00	0.31%	0.07%
10	6	0.068	0.068	0.00	-0.64%	0.15%
10	7	0.068	0.068	0.00	-0.17%	0.04%
10	8	0.067	0.067	0.00	-0.23%	0.05%
10	9	0.067	0.067	0.00	-0.19%	0.04%
20	10	0.068	0.067	0.00	-0.74%	0.17%
20	11	0.068	0.068	0.00	0.05%	0.01%
20	12	0.069	0.069	0.00	-0.23%	0.05%
20	13	0.069	0.068	0.00	-0.39%	0.09%
20	14	0.067	0.067	0.00	-0.15%	0.03%
30	15	0.069	0.068	0.00	-0.56%	0.13%
30	16	0.069	0.068	0.00	-0.65%	0.15%
30	17	0.068	0.068	0.00	-0.09%	0.02%
30	18	0.068	0.068	0.00	-0.59%	0.14%
30	19	0.068	0.068	0.00	-0.14%	0.03%
30	20	0.068	0.068	0.00	-0.57%	0.13%
31	21	0.069	0.068	0.00	-0.55%	0.12%
31	22	0.069	0.068	0.00	-0.38%	0.09%
31	23	0.068	0.068	0.00	0.09%	0.02%
31	24	0.068	0.068	0.00	-0.50%	0.11%
31	25	0.068	0.068	0.00	0.00%	0.00%
31	26	0.068	0.068	0.00	-0.20%	0.05%
50	27	0.069	0.068	0.00	-0.59%	0.14%
50	28	0.068	0.068	0.00	-0.09%	0.02%
50	29	0.067	0.067	0.00	-0.37%	0.08%
50	30	0.067	0.067	0.00	-0.14%	0.03%
50	31	0.067	0.067	0.00	-0.33%	0.07%
Max		0.069	0.069	0.00	0.37%	0.17%
Average		0.068	0.068	0.00	-0.22%	0.07%
Min		0.067	0.067	0.00	-0.74%	0.00%
Std Dev		0.001	0.000	0.00	0.32%	0.05%



TID Report

SN54SC6T07-SEP




VOL_3MA_2P75V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.2					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.059	0.059	0.00	0.16%	0.03%
0	2	0.060	0.060	0.00	0.37%	0.07%
0	3	0.059	0.060	0.00	0.38%	0.08%
0	4	0.060	0.060	0.00	0.28%	0.06%
10	5	0.060	0.060	0.00	-0.02%	0.00%
10	6	0.060	0.060	0.00	-0.42%	0.08%
10	7	0.060	0.060	0.00	0.07%	0.01%
10	8	0.060	0.060	0.00	-0.05%	0.01%
10	9	0.060	0.060	0.00	-0.05%	0.01%
20	10	0.060	0.059	0.00	-0.42%	0.08%
20	11	0.061	0.061	0.00	-0.15%	0.03%
20	12	0.061	0.061	0.00	0.10%	0.02%
20	13	0.061	0.061	0.00	-0.15%	0.03%
20	14	0.060	0.060	0.00	-0.18%	0.03%
30	15	0.061	0.060	0.00	-0.98%	0.20%
30	16	0.061	0.061	0.00	-0.12%	0.02%
30	17	0.061	0.060	0.00	-0.36%	0.07%
30	18	0.060	0.060	0.00	-0.52%	0.10%
30	19	0.060	0.060	0.00	-0.36%	0.07%
30	20	0.060	0.060	0.00	-0.33%	0.07%
31	21	0.061	0.060	0.00	-0.46%	0.09%
31	22	0.061	0.061	0.00	0.05%	0.01%
31	23	0.061	0.061	0.00	0.41%	0.08%
31	24	0.060	0.060	0.00	-0.10%	0.02%
31	25	0.060	0.060	0.00	-0.47%	0.09%
31	26	0.060	0.060	0.00	-0.10%	0.02%
50	27	0.061	0.060	0.00	-0.57%	0.11%
50	28	0.060	0.060	0.00	-0.21%	0.04%
50	29	0.060	0.060	0.00	-0.11%	0.02%
50	30	0.060	0.059	0.00	-0.26%	0.05%
50	31	0.060	0.059	0.00	-0.47%	0.09%
Max		0.061	0.061	0.00	0.41%	0.20%
Average		0.060	0.060	0.00	-0.15%	0.06%
Min		0.059	0.059	0.00	-0.98%	0.00%
Std Dev		0.001	0.000	0.00	0.31%	0.04%



TID Report

SN54SC6T07-SEP




VOL_5P5MA_3P6V						
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.096	0.096	0.00	-0.10%	0.03%
0	2	0.097	0.097	0.00	0.16%	0.04%
0	3	0.097	0.097	0.00	0.14%	0.04%
0	4	0.098	0.098	0.00	0.33%	0.09%
10	5	0.097	0.097	0.00	0.04%	0.01%
10	6	0.097	0.097	0.00	0.04%	0.01%
10	7	0.097	0.097	0.00	0.03%	0.01%
10	8	0.097	0.097	0.00	-0.25%	0.07%
10	9	0.097	0.097	0.00	-0.29%	0.08%
20	10	0.097	0.097	0.00	0.06%	0.02%
20	11	0.099	0.099	0.00	0.34%	0.10%
20	12	0.099	0.099	0.00	-0.03%	0.01%
20	13	0.099	0.099	0.00	-0.19%	0.05%
20	14	0.097	0.097	0.00	0.00%	0.00%
30	15	0.099	0.099	0.00	-0.16%	0.04%
30	16	0.099	0.099	0.00	-0.40%	0.11%
30	17	0.099	0.099	0.00	-0.32%	0.09%
30	18	0.099	0.099	0.00	-0.28%	0.08%
30	19	0.098	0.098	0.00	-0.25%	0.07%
30	20	0.099	0.098	0.00	-0.41%	0.12%
31	21	0.099	0.099	0.00	-0.22%	0.06%
31	22	0.099	0.099	0.00	-0.11%	0.03%
31	23	0.099	0.099	0.00	-0.06%	0.02%
31	24	0.099	0.099	0.00	-0.03%	0.01%
31	25	0.098	0.098	0.00	-0.06%	0.02%
31	26	0.099	0.099	0.00	-0.13%	0.04%
50	27	0.099	0.099	0.00	-0.43%	0.12%
50	28	0.098	0.098	0.00	0.60%	0.17%
50	29	0.098	0.097	0.00	-0.42%	0.12%
50	30	0.097	0.097	0.00	0.13%	0.04%
50	31	0.097	0.097	0.00	-0.06%	0.02%
Max		0.099	0.099	0.00	0.60%	0.17%
Average		0.098	0.098	0.00	-0.08%	0.06%
Min		0.096	0.096	0.00	-0.43%	0.00%
Std Dev		0.001	0.001	0.00	0.24%	0.04%



TID Report

SN54SC6T07-SEP




VOL_5P5MA_3V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.25					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.104	0.104	0.00	0.09%	0.03%
0	2	0.105	0.105	0.00	-0.03%	0.01%
0	3	0.105	0.105	0.00	0.04%	0.01%
0	4	0.106	0.106	0.00	0.08%	0.03%
10	5	0.105	0.105	0.00	-0.10%	0.03%
10	6	0.105	0.105	0.00	-0.04%	0.01%
10	7	0.105	0.105	0.00	0.01%	0.00%
10	8	0.105	0.105	0.00	-0.12%	0.04%
10	9	0.105	0.105	0.00	0.03%	0.01%
20	10	0.105	0.105	0.00	-0.30%	0.09%
20	11	0.107	0.107	0.00	0.01%	0.00%
20	12	0.107	0.107	0.00	-0.03%	0.01%
20	13	0.107	0.107	0.00	-0.13%	0.04%
20	14	0.105	0.105	0.00	-0.15%	0.04%
30	15	0.107	0.106	0.00	-0.61%	0.19%
30	16	0.107	0.107	0.00	-0.31%	0.09%
30	17	0.107	0.107	0.00	-0.50%	0.15%
30	18	0.106	0.106	0.00	-0.18%	0.05%
30	19	0.107	0.106	0.00	-0.53%	0.16%
30	20	0.107	0.106	0.00	-0.50%	0.15%
31	21	0.107	0.107	0.00	-0.37%	0.11%
31	22	0.107	0.107	0.00	-0.10%	0.03%
31	23	0.107	0.107	0.00	0.00%	0.00%
31	24	0.106	0.106	0.00	0.00%	0.00%
31	25	0.107	0.106	0.00	-0.29%	0.09%
31	26	0.107	0.106	0.00	-0.09%	0.03%
50	27	0.107	0.107	0.00	-0.41%	0.13%
50	28	0.105	0.106	0.00	0.30%	0.09%
50	29	0.105	0.105	0.00	-0.05%	0.02%
50	30	0.105	0.105	0.00	-0.12%	0.04%
50	31	0.105	0.104	0.00	-0.27%	0.08%
Max		0.107	0.107	0.00	0.30%	0.19%
Average		0.106	0.106	0.00	-0.15%	0.06%
Min		0.104	0.104	0.00	-0.61%	0.00%
Std Dev		0.001	0.001	0.00	0.21%	0.06%



TID Report

SN54SC6T07-SEP




VOL_8MA_4P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.35					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.131	0.131	0.00	0.10%	0.03%
0	2	0.132	0.132	0.00	0.12%	0.03%
0	3	0.131	0.132	0.00	0.48%	0.14%
0	4	0.132	0.133	0.00	0.35%	0.10%
10	5	0.131	0.131	0.00	0.05%	0.01%
10	6	0.133	0.132	0.00	-0.21%	0.06%
10	7	0.132	0.132	0.00	-0.12%	0.03%
10	8	0.132	0.132	0.00	-0.09%	0.03%
10	9	0.132	0.132	0.00	-0.07%	0.02%
20	10	0.132	0.131	0.00	-0.31%	0.09%
20	11	0.134	0.134	0.00	0.02%	0.01%
20	12	0.135	0.135	0.00	-0.14%	0.04%
20	13	0.135	0.134	0.00	-0.21%	0.06%
20	14	0.132	0.132	0.00	-0.21%	0.06%
30	15	0.135	0.134	0.00	-0.33%	0.10%
30	16	0.135	0.134	0.00	-0.53%	0.16%
30	17	0.134	0.134	0.00	-0.05%	0.01%
30	18	0.134	0.134	0.00	-0.28%	0.08%
30	19	0.134	0.134	0.00	-0.26%	0.08%
30	20	0.134	0.134	0.00	-0.35%	0.10%
31	21	0.135	0.134	0.00	-0.23%	0.07%
31	22	0.135	0.135	0.00	-0.09%	0.03%
31	23	0.134	0.135	0.00	0.14%	0.04%
31	24	0.134	0.134	0.00	-0.12%	0.03%
31	25	0.134	0.134	0.00	0.07%	0.02%
31	26	0.134	0.134	0.00	0.00%	0.00%
50	27	0.135	0.134	0.00	-0.56%	0.17%
50	28	0.133	0.133	0.00	0.57%	0.17%
50	29	0.132	0.132	0.00	-0.21%	0.06%
50	30	0.132	0.132	0.00	-0.05%	0.01%
50	31	0.132	0.131	0.00	-0.21%	0.06%
Max		0.135	0.135	0.00	0.57%	0.17%
Average		0.133	0.133	0.00	-0.08%	0.06%
Min		0.131	0.131	0.00	-0.56%	0.00%
Std Dev		0.001	0.001	0.00	0.26%	0.05%



TID Report

SN54SC6T07-SEP




VOL_8MA_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.35					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.125	0.125	0.00	-0.02%	0.01%
0	2	0.127	0.127	0.00	0.02%	0.01%
0	3	0.126	0.126	0.00	0.02%	0.01%
0	4	0.127	0.127	0.00	0.15%	0.04%
10	5	0.126	0.125	0.00	-0.25%	0.07%
10	6	0.127	0.127	0.00	-0.15%	0.04%
10	7	0.126	0.126	0.00	-0.07%	0.02%
10	8	0.127	0.126	0.00	-0.37%	0.10%
10	9	0.126	0.126	0.00	-0.12%	0.03%
20	10	0.126	0.126	0.00	-0.12%	0.03%
20	11	0.129	0.129	0.00	0.17%	0.05%
20	12	0.129	0.129	0.00	0.00%	0.00%
20	13	0.129	0.129	0.00	-0.12%	0.03%
20	14	0.126	0.126	0.00	-0.22%	0.06%
30	15	0.129	0.129	0.00	-0.12%	0.03%
30	16	0.129	0.128	0.00	-0.29%	0.08%
30	17	0.129	0.129	0.00	-0.07%	0.02%
30	18	0.129	0.128	0.00	-0.32%	0.09%
30	19	0.128	0.128	0.00	-0.24%	0.07%
30	20	0.129	0.128	0.00	-0.24%	0.07%
31	21	0.129	0.129	0.00	-0.15%	0.04%
31	22	0.129	0.129	0.00	0.07%	0.02%
31	23	0.129	0.129	0.00	-0.05%	0.01%
31	24	0.129	0.128	0.00	-0.10%	0.03%
31	25	0.128	0.128	0.00	0.12%	0.03%
31	26	0.129	0.129	0.00	-0.07%	0.02%
50	27	0.129	0.128	0.00	-0.39%	0.11%
50	28	0.127	0.128	0.00	0.84%	0.24%
50	29	0.126	0.126	0.00	-0.15%	0.04%
50	30	0.126	0.126	0.00	-0.07%	0.02%
50	31	0.126	0.126	0.00	-0.30%	0.08%
Max		0.129	0.129	0.00	0.84%	0.24%
Average		0.128	0.127	0.00	-0.08%	0.05%
Min		0.125	0.125	0.00	-0.39%	0.00%
Std Dev		0.001	0.001	0.00	0.22%	0.05%



TID Report

SN54SC6T07-SEP




VOL_24MA_4P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.75					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.397	0.397	0.00	0.02%	0.01%
0	2	0.401	0.401	0.00	0.00%	0.00%
0	3	0.398	0.398	0.00	0.17%	0.08%
0	4	0.401	0.402	0.00	0.08%	0.04%
10	5	0.398	0.398	0.00	-0.13%	0.06%
10	6	0.402	0.400	0.00	-0.32%	0.15%
10	7	0.400	0.400	0.00	-0.14%	0.07%
10	8	0.400	0.400	0.00	-0.08%	0.04%
10	9	0.399	0.399	0.00	-0.18%	0.08%
20	10	0.399	0.398	0.00	-0.23%	0.11%
20	11	0.407	0.407	0.00	-0.07%	0.03%
20	12	0.408	0.408	0.00	-0.05%	0.03%
20	13	0.408	0.407	0.00	-0.24%	0.11%
20	14	0.399	0.399	0.00	-0.15%	0.07%
30	15	0.409	0.407	0.00	-0.39%	0.19%
30	16	0.408	0.406	0.00	-0.31%	0.15%
30	17	0.408	0.407	0.00	-0.23%	0.11%
30	18	0.407	0.406	0.00	-0.22%	0.11%
30	19	0.406	0.405	0.00	-0.26%	0.13%
30	20	0.407	0.406	0.00	-0.35%	0.17%
31	21	0.409	0.408	0.00	-0.26%	0.13%
31	22	0.408	0.407	0.00	-0.07%	0.03%
31	23	0.408	0.408	0.00	0.05%	0.02%
31	24	0.407	0.406	0.00	-0.07%	0.03%
31	25	0.406	0.405	0.00	-0.06%	0.03%
31	26	0.407	0.407	0.00	-0.08%	0.04%
50	27	0.408	0.406	0.00	-0.50%	0.24%
50	28	0.401	0.404	0.00	0.70%	0.33%
50	29	0.400	0.399	0.00	-0.30%	0.14%
50	30	0.399	0.398	0.00	-0.33%	0.15%
50	31	0.399	0.398	0.00	-0.22%	0.10%
Max		0.409	0.408	0.00	0.70%	0.33%
Average		0.404	0.403	0.00	-0.13%	0.10%
Min		0.397	0.397	0.00	-0.50%	0.00%
Std Dev		0.004	0.004	0.00	0.22%	0.07%



TID Report

SN54SC6T07-SEP




VOL_24MA_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.75					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.378	0.378	0.00	0.12%	0.05%
0	2	0.383	0.383	0.00	0.01%	0.00%
0	3	0.379	0.380	0.00	0.19%	0.08%
0	4	0.383	0.383	0.00	0.07%	0.03%
10	5	0.380	0.379	0.00	-0.07%	0.03%
10	6	0.383	0.382	0.00	-0.31%	0.14%
10	7	0.382	0.382	0.00	-0.14%	0.06%
10	8	0.382	0.382	0.00	-0.08%	0.04%
10	9	0.381	0.380	0.00	-0.11%	0.05%
20	10	0.380	0.380	0.00	-0.21%	0.09%
20	11	0.389	0.389	0.00	0.05%	0.02%
20	12	0.390	0.389	0.00	-0.08%	0.04%
20	13	0.389	0.388	0.00	-0.10%	0.05%
20	14	0.380	0.380	0.00	-0.07%	0.03%
30	15	0.390	0.389	0.00	-0.30%	0.14%
30	16	0.389	0.388	0.00	-0.27%	0.13%
30	17	0.389	0.389	0.00	-0.14%	0.06%
30	18	0.388	0.387	0.00	-0.24%	0.11%
30	19	0.387	0.386	0.00	-0.27%	0.12%
30	20	0.389	0.387	0.00	-0.32%	0.14%
31	21	0.390	0.389	0.00	-0.19%	0.09%
31	22	0.389	0.389	0.00	-0.11%	0.05%
31	23	0.389	0.389	0.00	-0.02%	0.01%
31	24	0.388	0.388	0.00	-0.06%	0.03%
31	25	0.387	0.387	0.00	0.03%	0.01%
31	26	0.389	0.388	0.00	-0.05%	0.02%
50	27	0.390	0.388	0.00	-0.47%	0.21%
50	28	0.383	0.386	0.00	0.78%	0.35%
50	29	0.382	0.381	0.00	-0.31%	0.14%
50	30	0.381	0.380	0.00	-0.21%	0.09%
50	31	0.381	0.380	0.00	-0.28%	0.13%
Max		0.390	0.389	0.00	0.78%	0.35%
Average		0.385	0.385	0.00	-0.10%	0.08%
Min		0.378	0.378	0.00	-0.47%	0.00%
Std Dev		0.004	0.004	0.00	0.22%	0.07%



TID Report

SN54SC6T07-SEP


VOL_50UA_1P2V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.1					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.002	0.002	0.00	-1.38%	0.02%
0	2	0.002	0.002	0.00	10.43%	0.11%
0	3	0.002	0.002	0.00	-4.09%	0.05%
0	4	0.002	0.002	0.00	-6.82%	0.08%
10	5	0.002	0.002	0.00	-1.38%	0.02%
10	6	0.002	0.002	0.00	1.13%	0.01%
10	7	0.002	0.002	0.00	5.94%	0.06%
10	8	0.002	0.002	0.00	1.40%	0.02%
10	9	0.002	0.002	0.00	-9.95%	0.11%
20	10	0.002	0.002	0.00	-6.82%	0.08%
20	11	0.002	0.002	0.00	-1.36%	0.02%
20	12	0.002	0.002	0.00	-5.70%	0.07%
20	13	0.002	0.002	0.00	-2.76%	0.03%
20	14	0.002	0.002	0.00	-0.27%	0.00%
30	15	0.002	0.002	0.00	-1.69%	0.02%
30	16	0.002	0.002	0.00	-5.53%	0.06%
30	17	0.002	0.002	0.00	3.01%	0.03%
30	18	0.002	0.002	0.00	-3.77%	0.04%
30	19	0.002	0.002	0.00	-5.69%	0.06%
30	20	0.002	0.002	0.00	1.42%	0.02%
31	21	0.002	0.002	0.00	3.86%	0.04%
31	22	0.002	0.002	0.00	-5.53%	0.06%
31	23	0.002	0.002	0.00	0.00%	0.00%
31	24	0.002	0.002	0.00	-10.76%	0.13%
31	25	0.002	0.002	0.00	-4.27%	0.05%
31	26	0.002	0.002	0.00	-1.42%	0.02%
50	27	0.002	0.002	0.00	2.76%	0.03%
50	28	0.002	0.002	0.00	-2.98%	0.03%
50	29	0.002	0.002	0.00	-1.40%	0.02%
50	30	0.002	0.002	0.00	5.69%	0.06%
50	31	0.002	0.002	0.00	-4.09%	0.05%
Max		0.002	0.002	0.00	10.43%	0.13%
Average		0.002	0.002	0.00	-1.60%	0.04%
Min		0.002	0.002	0.00	-10.76%	0.00%
Std Dev		0.000	0.000	0.00	4.73%	0.03%




TID Report

SN54SC6T07-SEP

VOL_50UA_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.1					
Min Limit	-0.1					
krad	Serial #	PreTestHDR	PostTestHDR	Delta	Delta %	% of Limit Range
0	1	0.001	0.001	0.00	-11.87%	0.05%
0	2	0.001	0.001	0.00	15.51%	0.05%
0	3	0.001	0.001	0.00	20.28%	0.06%
0	4	0.001	0.001	0.00	-21.18%	0.09%
10	5	0.001	0.001	0.00	-8.96%	0.03%
10	6	0.001	0.001	0.00	20.28%	0.06%
10	7	0.001	0.001	0.00	-12.33%	0.05%
10	8	0.001	0.001	0.00	4.32%	0.01%
10	9	0.001	0.001	0.00	-8.90%	0.03%
20	10	0.001	0.001	0.00	4.94%	0.02%
20	11	0.001	0.001	0.00	-20.54%	0.08%
20	12	0.001	0.001	0.00	25.95%	0.08%
20	13	0.001	0.001	0.00	-15.82%	0.07%
20	14	0.001	0.001	0.00	-12.82%	0.05%
30	15	0.001	0.001	0.00	-3.51%	0.01%
30	16	0.001	0.001	0.00	-16.17%	0.06%
30	17	0.001	0.001	0.00	12.69%	0.05%
30	18	0.001	0.001	0.00	3.96%	0.02%
30	19	0.001	0.001	0.00	8.69%	0.03%
30	20	0.001	0.001	0.00	5.32%	0.02%
31	21	0.001	0.001	0.00	-11.13%	0.05%
31	22	0.001	0.001	0.00	-16.17%	0.06%
31	23	0.001	0.001	0.00	-24.41%	0.09%
31	24	0.001	0.001	0.00	-7.61%	0.03%
31	25	0.001	0.001	0.00	-8.52%	0.03%
31	26	0.001	0.001	0.00	0.38%	0.00%
50	27	0.001	0.001	0.00	18.13%	0.06%
50	28	0.001	0.001	0.00	8.24%	0.03%
50	29	0.001	0.001	0.00	12.52%	0.05%
50	30	0.001	0.001	0.00	7.32%	0.03%
50	31	0.001	0.001	0.00	12.64%	0.04%
Max		0.001	0.001	0.00	25.95%	0.09%
Average		0.001	0.001	0.00	-1.05%	0.04%
Min		0.001	0.001	0.00	-24.41%	0.00%
Std Dev		0.000	0.000	0.00	14.09%	0.02%



VOL_50UA_5P5V						
Test Site	SLAB					
Tester	ETS88B					
Test Number	EQ774300					
Units	V					
Max Limit	0.1					
Min Limit	-0.1					
krad	0	10	20	30	31	50
LL	-0.10	-0.10	-0.10	-0.10	-0.10	-0.10
Min	0.00	0.00	0.00	0.00	0.00	0.00
Average	0.00	0.00	0.00	0.00	0.00	0.00
Max	0.00	0.00	0.00	0.00	0.00	0.00
UL	0.10	0.10	0.10	0.10	0.10	0.10



IMPORTANT NOTICE AND DISCLAIMER

TI PROVIDES TECHNICAL AND RELIABILITY DATA (INCLUDING DATA SHEETS), DESIGN RESOURCES (INCLUDING REFERENCE DESIGNS), APPLICATION OR OTHER DESIGN ADVICE, WEB TOOLS, SAFETY INFORMATION, AND OTHER RESOURCES "AS IS" AND WITH ALL FAULTS, AND DISCLAIMS ALL WARRANTIES, EXPRESS AND IMPLIED, INCLUDING WITHOUT LIMITATION ANY IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR NON-INFRINGEMENT OF THIRD PARTY INTELLECTUAL PROPERTY RIGHTS.

These resources are intended for skilled developers designing with TI products. You are solely responsible for (1) selecting the appropriate TI products for your application, (2) designing, validating and testing your application, and (3) ensuring your application meets applicable standards, and any other safety, security, regulatory or other requirements.

These resources are subject to change without notice. TI grants you permission to use these resources only for development of an application that uses the TI products described in the resource. Other reproduction and display of these resources is prohibited. No license is granted to any other TI intellectual property right or to any third party intellectual property right. TI disclaims responsibility for, and you will fully indemnify TI and its representatives against, any claims, damages, costs, losses, and liabilities arising out of your use of these resources.

TI's products are provided subject to [TI's Terms of Sale](#) or other applicable terms available either on [ti.com](#) or provided in conjunction with such TI products. TI's provision of these resources does not expand or otherwise alter TI's applicable warranties or warranty disclaimers for TI products.

TI objects to and rejects any additional or different terms you may have proposed.

Mailing Address: Texas Instruments, Post Office Box 655303, Dallas, Texas 75265
Copyright © 2024, Texas Instruments Incorporated