

Prasad Dhond,
Marketing Manager,
Smart Grid

Texas Instruments

Sub-metering made easy using Texas Instruments energy measurement ICs

Introduction

Sub-metering applications such as smart plugs and appliance energy meters enable consumers to understand and control their energy-usage patterns. Other sub-metering applications such as server power meters help IT departments optimize power consumption of server farms. When designing a sub-meter, considerations such as choice of sensors, analog front-end (AFE) components, and microcontrollers (MCUs) play an important role in determining the overall system cost and complexity. An effective implementation should be easy to design and low cost to mass produce while fulfilling the main requirements of the application – to reliably measure and report energy consumption information. This white paper discusses features and benefits of the MSP430AFE2xx IC¹ in energy measurement applications. While the MSP430AFE2xx is completely suitable for energy measurement in utility-grade electricity meters, this white paper specifically discusses its use in sub-metering. In the context of this white paper, sub-metering refers to non-utility electricity metering applications such as smart plugs, appliance energy meters and server power meters.

Functions of a sub-meter

Sub-meters may be in the form of a smart plug (Figure 1 below) or they may be integrated in an appliance (Figure 2 on the following page) or server. In either case, a sub-meter typically performs the following functions:

- Measures real-time energy consumption of an appliance.
- Communicates the energy consumption data to the user. This can be done with a simple LCD readout on the sub-meter itself. Alternately, the sub-meter can send the data to a remote terminal wirelessly using Wi-Fi™ or ZigBee®, or through a wired communication method such as a serial port or power line communication (PLC).
- The sub-meter may optionally have the capability to regulate power being supplied to the appliance. For example, to shut off the appliance during peak load hours or to control it from a remote location.

Components of energy measurement

An energy measurement system requires voltage and current sensors, an AFE to interface with these sensors and an MCU to perform energy measurement calculations. The energy measurement results can be displayed on an LCD screen or sent over the serial bus to another device for wireless communication as shown in Figure 2 on the following page.



Figure 1: MSP430™ Energy Watchdog² smart plug reference design




Figure 2: Block diagram of an energy measurement system

Power is the product of instantaneous voltage and current. As shown in the formula below, active energy is power accumulated over time and is expressed in kilowatt-hours (kWh).

$$\text{Active Energy} = \frac{1}{N} \sum_{i=1}^N V_{\text{samp}}(i) * I_{\text{samp}}(i)$$

Where V_{samp} is Voltage Sample, I_{samp} is Current Sample, N is Sample Count

The first step in energy measurement is to measure the incoming voltage and load current using voltage and current sensors respectively.

Choosing voltage and current sensors

In sub-meters, simple resistor dividers can be used as voltage sensors. The resistor values are chosen to divide down the AC mains voltage (usually 230 VAC or 120 VAC) to fit the input range of the analog-to-digital converter (ADC). The resistor-divider circuit shown in Figure 3 can be used to divide down mains voltage of 230 VAC to around 350 mV RMS, which is 495 mV peak, before being fed to the positive input of the ADC³. Resistors have maximum voltage ratings, which if exceeded, can cause arcing over the body of the resistor. The use of discrete resistors (R1, R2, and R3) in series instead of a single 1MΩ resistor allows use of




Figure 3: Voltage-sensing circuit for the MSP430AFE2xx energy measurement IC

standard resistors without exceeding their maximum voltage ratings. An alternate choice of voltage sensors is voltage transformers that can provide isolation from the high-voltage mains. However, voltage transformers are expensive compared with discrete resistors.

The choice of current sensors depends on the type of incoming mains that the appliance uses. In the U.S., appliances such as refrigerators and washing machines run on single-phase 120 VAC, whereas high-power appliances such as clothes dryers and electric cooking ranges operate on split-phase 240 VAC. For single-phase applications, a low-value shunt resistor can be placed in the neutral line (Figure 4) and the voltage drop across the shunt can be measured to calculate the current. The value of the shunt resistor is determined by the range of load currents, gain settings of the ADC and the power dissipation at the sensors. Shunt resistors are low cost and easy to use, but they do not provide electrical isolation. For appliances such as clothes dryers and cooking ranges that use a split-phase supply, current transformers must be used on each of the two live wires. Current transformers provide electrical isolation, but cost more than shunts.




Figure 4: Current-sensing circuit for the MSP430AFE2xx energy measurement IC

The sensing stage is followed by passive interface circuitry that further conditions the input signals before being fed into the ADC. This circuitry includes a filter to remove spurious wideband noise that can lead to inaccurate measurements. For single-phase appliances such as refrigerators, two ADCs are needed: one to measure the voltage and another to measure the current. For clothes dryers and cooking ranges, four ADCs are needed to measure two voltages and two currents. ADCs with 16-bit or 24-bit resolution and simultaneous sampling capability can be used to generate accurate energy-measurement results.

Energy measurement and reporting

Energy measurement calculations are performed on the voltage and current samples collected by the ADC. As seen from the formulae below, to compute active energy, reactive energy or apparent energy, MCUs must have good math libraries for common functions such as square root, square and division.

$$V_{\text{RMS}} = \sqrt{\frac{1}{N} \sum_{i=1}^N V_{\text{samp}}(i) * V_{\text{samp}}(i)} \quad I_{\text{RMS}} = \sqrt{\frac{1}{N} \sum_{i=1}^N I_{\text{samp}}(i) * I_{\text{samp}}(i)}$$

$$\text{Active Energy} = \frac{1}{N} \sum_{i=1}^N V_{\text{samp}}(i) * I_{\text{samp}}(i)$$

$$\text{Apparent Energy} = V_{\text{RMS}} * I_{\text{RMS}}$$

$$\text{Reactive Energy}_{\text{PT}} = \sqrt{\text{Apparent Energy}^2 - \text{Active Energy}^2}$$

$$\text{Power Factor} = \cos \phi = \frac{\text{Active Energy}}{\text{Apparent Energy}}$$

Where V_{samp} is Voltage Sample, I_{samp} is Current Sample, N is Sample Count

Once energy measurement results have been calculated, they can be displayed on an LCD on the sub-meter itself or on a remote terminal. The MCU can be interfaced with LCD drivers or wireless communication modules via serial communication interfaces. If non-isolating sensors such as shunts and voltage dividers are used or if the AFE and MCU are referenced to the mains, it is critical to isolate any connection to other devices or systems that use a different reference voltage. Optocouplers or capacitive isolation ICs can be used to implement this isolation.

An energy measurement system using low-power components can be powered using a simple capacitive power supply. However, a capacitive power supply does not provide enough current to drive RF transceivers. Sub-meters that use Wi-Fi™ or ZigBee® to transmit energy consumption data will need an additional NPN output buffer or a transformer and switching-based power supply to power the RF transceivers.

Calibration

There could be differences in energy measurement values from one meter to another due to component and sensor tolerances. Electricity meters from utilities have stringent accuracy requirements and errors due to component tolerances must be calibrated out on each unit. However, sub-meters such as smart plugs and appliance energy meters typically have more relaxed accuracy requirements since their energy measurement results are not used for billing purposes. Calibration constants for a design can be determined during development and programmed in the MCU Flash memory, eliminating the need to calibrate each unit in production. It is estimated that an accuracy of <3 percent can be achieved with this approach. This accuracy is sufficient in many sub-meter applications and the elimination of calibration can result in significant cost savings in production.

MSP430AFE2xx energy measurement IC

The MSP430AFE2xx energy measurement IC integrates multiple 24-bit sigma-delta ADCs, programmable gain amplifiers and a 16-bit MCU in a single package. This device is accompanied by TI's MSP430™ MCU Energy Library⁴ software to implement energy-measurement calculations.




Figure 5: Features of the MSP430AFE2xx for energy-measurement applications

Developers will experience the following key features and benefits when using the MSP430AFE2xx energy measurement IC for sub-meters:

High level of integration

The MSP430AFE2xx integrates several components required for energy measurement including the ADCs and the MCU. This enables low-cost and small-footprint sub-meter designs that use a minimum number of components. In addition to energy measurement, the MSP430AFE2xx MCU can also be used for running other small applications as needed.

Multiple 24-bit sigma-delta ADCs

Each of the three ADCs supports a differential input voltage of ± 500 mV, so outputs from the current sensor can be fed directly to the ADC without the need for level shifting. The ADC inputs also support a negative input voltage of up to -1 V which allows the divided down voltage signal from the AC mains to be also interfaced directly to the ADC without additional level shifting.

The MSP430AFE2xx offers up to three sigma-delta ADCs with 24-bit resolution. These ADCs are capable of providing utility grade (<0.1 percent) accuracy over a wide range of load currents. The simultaneous sampling feature of the ADCs eliminates inherent delay between the current and voltage samples and eliminates the need for software compensation, an anomaly of the sequential sampling approach.

Low-power consumption

Low-power consumption of the MSP430AFE2xx energy measurement IC is important in being able to use a low-cost capacitive supply to power the device.

Software programmability

The MSP430™ MCU Energy Library and sample code from TI allow quick and easy implementation of energy measurement calculations on the MSP430AFE2xx.

A key advantage of a software-programmable solution like the MSP430AFE2xx is that it provides flexibility to the system designer to tailor the solution to specific application needs. For example, the system designer can implement a non-standard communication protocol to send energy consumption data to a host processor or to a remote terminal. Another advantage of the software-programmable energy measurement IC is the possible elimination of calibration during production.

Serial communication interfaces and GPIOs

The MSP430AFE2xx allows energy-consumption data to be sent over a standard serial interface such as SPI or UART. Its additional GPIOs can be used to implement LCD interface, LED pulse generation or to interface with inputs such as keys.

Summary

Low-cost components that perform energy measurement are important in achieving widespread adoption of energy measurement in smart plugs, appliances and servers. The MSP430AFE2xx energy measurement IC includes the key components required for energy measurement, all in a single package. This includes programmable gain amplifiers, ADCs, MCU as well as serial interfaces to communicate with other devices. The MSP430AFE2xx can be interfaced with low-cost sensors such as shunt resistors and voltage dividers with only a few passive components. The ultra-low-power performance of the MSP430 family of microcontrollers allows use of a low-cost capacitive power supply to power the MSP430AFE2xx. Since this solution is software programmable, it allows flexibility to implement non-standard communication protocols. Finally, once calibration is performed during development, the same calibration constants can be programmed into each MSP430AFE2xx unit during production to easily achieve 3 percent or better accuracy. This elimination of calibration during production has the potential to significantly lower production costs.

References

- ¹ MSP430AFE2xx Datasheet, <http://www.ti.com/lit/slas701>
- ² MSP430 Energy Watchdog Tool, <http://www.ti.com/tool/msp-nrgwtchdg>
- ³ Implementation of a Single-Phase Electronic Watt-Hour Meter Using the MSP430AFE2xx, TI Application Report SLAA494, <http://www.ti.com/lit/slaa494>
- ⁴ MSP430 Energy Library Software Suite, <http://www.ti.com/tool/msp430-energy-library>

Important Notice: The products and services of Texas Instruments Incorporated and its subsidiaries described herein are sold subject to TI's standard terms and conditions of sale. Customers are advised to obtain the most current and complete information about TI products and services before placing orders. TI assumes no liability for applications assistance, customer's applications or product designs, software performance, or infringement of patents. The publication of information regarding any other company's products or services does not constitute TI's approval, warranty or endorsement thereof.

MSP430 is a trademark of Texas Instruments Incorporated. All other trademarks are the property of their respective owners.

IMPORTANT NOTICE

Texas Instruments Incorporated and its subsidiaries (TI) reserve the right to make corrections, modifications, enhancements, improvements, and other changes to its products and services at any time and to discontinue any product or service without notice. Customers should obtain the latest relevant information before placing orders and should verify that such information is current and complete. All products are sold subject to TI's terms and conditions of sale supplied at the time of order acknowledgment.

TI warrants performance of its hardware products to the specifications applicable at the time of sale in accordance with TI's standard warranty. Testing and other quality control techniques are used to the extent TI deems necessary to support this warranty. Except where mandated by government requirements, testing of all parameters of each product is not necessarily performed.

TI assumes no liability for applications assistance or customer product design. Customers are responsible for their products and applications using TI components. To minimize the risks associated with customer products and applications, customers should provide adequate design and operating safeguards.

TI does not warrant or represent that any license, either express or implied, is granted under any TI patent right, copyright, mask work right, or other TI intellectual property right relating to any combination, machine, or process in which TI products or services are used. Information published by TI regarding third-party products or services does not constitute a license from TI to use such products or services or a warranty or endorsement thereof. Use of such information may require a license from a third party under the patents or other intellectual property of the third party, or a license from TI under the patents or other intellectual property of TI.

Reproduction of TI information in TI data books or data sheets is permissible only if reproduction is without alteration and is accompanied by all associated warranties, conditions, limitations, and notices. Reproduction of this information with alteration is an unfair and deceptive business practice. TI is not responsible or liable for such altered documentation. Information of third parties may be subject to additional restrictions.

Resale of TI products or services with statements different from or beyond the parameters stated by TI for that product or service voids all express and any implied warranties for the associated TI product or service and is an unfair and deceptive business practice. TI is not responsible or liable for any such statements.

TI products are not authorized for use in safety-critical applications (such as life support) where a failure of the TI product would reasonably be expected to cause severe personal injury or death, unless officers of the parties have executed an agreement specifically governing such use. Buyers represent that they have all necessary expertise in the safety and regulatory ramifications of their applications, and acknowledge and agree that they are solely responsible for all legal, regulatory and safety-related requirements concerning their products and any use of TI products in such safety-critical applications, notwithstanding any applications-related information or support that may be provided by TI. Further, Buyers must fully indemnify TI and its representatives against any damages arising out of the use of TI products in such safety-critical applications.

TI products are neither designed nor intended for use in military/aerospace applications or environments unless the TI products are specifically designated by TI as military-grade or "enhanced plastic." Only products designated by TI as military-grade meet military specifications. Buyers acknowledge and agree that any such use of TI products which TI has not designated as military-grade is solely at the Buyer's risk, and that they are solely responsible for compliance with all legal and regulatory requirements in connection with such use.

TI products are neither designed nor intended for use in automotive applications or environments unless the specific TI products are designated by TI as compliant with ISO/TS 16949 requirements. Buyers acknowledge and agree that, if they use any non-designated products in automotive applications, TI will not be responsible for any failure to meet such requirements.

Following are URLs where you can obtain information on other Texas Instruments products and application solutions:

Products

Audio	www.ti.com/audio
Amplifiers	amplifier.ti.com
Data Converters	dataconverter.ti.com
DLP® Products	www.dlp.com
DSP	dsp.ti.com
Clocks and Timers	www.ti.com/clocks
Interface	interface.ti.com
Logic	logic.ti.com
Power Mgmt	power.ti.com
Microcontrollers	microcontroller.ti.com
RFID	www.ti-rfid.com
OMAP Mobile Processors	www.ti.com/omap
Wireless Connectivity	www.ti.com/wirelessconnectivity

Applications

Automotive and Transportation	www.ti.com/automotive
Communications and Telecom	www.ti.com/communications
Computers and Peripherals	www.ti.com/computers
Consumer Electronics	www.ti.com/consumer-apps
Energy and Lighting	www.ti.com/energy
Industrial	www.ti.com/industrial
Medical	www.ti.com/medical
Security	www.ti.com/security
Space, Avionics and Defense	www.ti.com/space-avionics-defense
Video and Imaging	www.ti.com/video

TI E2E Community Home Page

e2e.ti.com

Mailing Address: Texas Instruments, Post Office Box 655303, Dallas, Texas 75265
Copyright © 2012, Texas Instruments Incorporated